

34
1924

Westinghouse
**RAILROAD
DATA**



Westinghouse Electric & Manufacturing Co.

East Pittsburgh, Penna.

IN view of the increasing interest among steam railroad men in the various applications of electricity to railroad operation, we are pleased to present these pages of

Westinghouse Railroad Data



Special
Publication 1707

**Westinghouse
Electric & Manufacturing Company
East Pittsburgh, Pa.**

Traction Data

ELECTRIC LOCOMOTIVES

Electric locomotives are built in a variety of types and sizes, employing several kinds of motors and methods of drive between the motors and drive wheels. The proper system of electrification and the best type of locomotive have been the subjects of much controversy. Each of the systems has a field of application and it is now felt that no one type or system should supersede all others. So much discussion has centered around these subjects that the reader will not here be burdened with such matter.

Data on several locomotives which have been built for heavy railroad service is given in the following pages. The railroad man who has had long experience with steam locomotives sometimes has difficulty in obtaining a correct conception of the meaning of electric locomotive ratings. A steam locomotive has a definite maximum tractive effort rating which is fixed by the dimensions of the cylinders, the driver diameter, and the boiler pressure. A steam locomotive generates its own power and can deliver tractive power only within the capacity of its own power plant, that is, the boiler and fire box. An electric locomotive, on the other hand, has behind it the capacity of the power plant and distribution system which is very large. The maximum tractive effort which an electric freight locomotive can exert is usually limited only by the adhesion between the drive wheels and the rails. This is sometimes true with passenger locomotives also, but it often happens that the current capacity of the motors is not sufficient to slip the drive wheels.

However, if an electric locomotive were permitted to exert for any considerable length of time the large tractive effort it is capable of producing by virtue of the enormous power behind it, the electrical equipment would be injured by overheating. It is therefore necessary to apply to electric locomotives, ratings which must always be associated with time limits. The two ratings most commonly given are the hourly rating and the continuous rating. The first indicates the capacity of the locomotive for one hour, assuming that the electrical equipment is at the temperature of the surrounding air at the start of the run. The continuous rating shows what tractive effort can be produced continuously without injuring the equipment. The question of ratings and their meaning will be amplified further under the heading of Locomotive Selection.

Westinghouse Electric & Manufacturing Company
East Pittsburgh, Penna.

CHICAGO, MILWAUKEE & ST. PAUL RAILWAY

DATA

Weights —Total	600,000 Lb.
On Drivers	378,000 Lb.
Per Driving Axle	63,000 Lb.
Ratings —One Hour, Short Field, T. E.	66,000 Lb.
Forced Ventilation	Speed... 26.7 M.p.h.
	Hp..... 4,680
Continuous, Short Field, T. E.	40,800 Lb.
	Speed... 31.2 M.p.h.
	Hp..... 3,400
Maximum Tractive Effort, 40.4% Adhesion,	
Limited by Motor Capacity	153,000 Lb.
Tractive Effort, 25% Adhesion	94,500 Lb.
Maximum Speed	65 M.p.h.
Number & Nominal Rating of Motors—Six Twin	780 Hp.
Gear Ratio	24:89
Driver Diameter	68 in.
Trolley Voltage	3,000 D-C.
Road Nos.	10301-10309


GENERAL INFORMATION

This locomotive was designed for heavy passenger service over mountain grades. It regularly hauls 960-ton passenger trains on a 440-mile run which includes 21 miles of grade averaging 1.72 percent with a maximum of 2 percent.

The locomotive consists of two Pacific type running gears coupled back to back and supporting a single cab which contains the control and auxiliary equipment. Each of the six driving axles is driven by a twin motor placed vertically above the axle. The drive between the motor and drive wheel is by single gearing and a quill which surrounds the axle but is connected to the wheels only by springs. The only non-spring borne weight is, therefore, the weight of the wheels and axles themselves. This gives a very flexible type of drive and a locomotive having very little damaging action on the track.

The control is arranged so that either twelve, six or four motor armatures can be connected in series between the trolley and rail. This gives three combinations of motors which, with two field shunt positions of the controller in each combination, makes a total of nine running speeds. The locomotive is equipped for regenerative braking. Two axle generators, one carried on each of the four-wheel engine trucks, supply excitation for the main motors when regenerating, and auxiliary power when motoring. In case of failure of the power supply, the axle generators can be used to furnish power for the air compressor and thus make it possible to descend a grade safely by air braking. An oil fired steam boiler is supplied for train heating.

Westinghouse Electric & Manufacturing Company
East Pittsburgh, Penna.



CHICAGO, MILWAUKEE & ST. PAUL RAILWAY

300-Ton Passenger Locomotive

PENNSYLVANIA RAILROAD FF-1 TYPE LOCOMOTIVE

DATA


Weights —Total.....	516,000 Lb.
On Drivers.....	439,500 Lb.
Per Driving Axle.....	73,250 Lb.
Ratings —One Hour, Forced Vent. T. E.....	88,000 Lb.
Speed.....	20.4 M.p.h.
Hp.....	4,800
Continuous T. E.....	73,000 Lb.
Speed.....	20.5 M.p.h.
Hp.....	4,000
Maximum Tractive Effort, 31.8% Adhesion, Limited by Motor Capacity.....	140,000 Lb.
Tractive Effort, 25% Adhesion.....	109,875 Lb.
Maximum Speed.....	35 M.p.h.
Number & Nominal Rating of Motors.....	4—1,200 Hp.
Gear Ratio.....	21:106
Driver Diameter.....	72 In.
Trolley Voltage.....	11,000 A-C.
Road No.....	3,931

GENERAL INFORMATION

This locomotive is the product of a joint design by the Pennsylvania Railroad Company and the Westinghouse Electric and Manufacturing Company. It was laid out for heavy, drag-freight service, such as is encountered on the Pennsylvania's line over the Allegheny Mountains. The wheel arrangement is 260 + 062 and the drive is by geared jack shaft and side rods. Each jack shaft carries two flexible gears which mesh with pinions on the shafts of two motors.

The motors on this locomotive are of the three-phase induction type and run at constant speed regardless of the amount of tractive effort they are supplying. Single-phase 25-cycle power is collected by the pantagraph from the overhead wire. This power passes through the main transformer and phase converter which together reduce its potential from 11,000 to 850 volts and convert it into three-phase power, suitable for the main motors. The phase converter is of the synchronous type serving to maintain high power factor in the distribution system. The motors can be connected in cascade to give a half-speed running position on the controller. This type of locomotive is inherently regenerative and no additional equipment is necessary to secure this feature.

Westinghouse Electric & Manufacturing Company
East Pittsburgh, Penna.



PENNSYLVANIA RAILROAD

PF-1 Type Locomotive

PENNSYLVANIA RAILROAD L-5 TYPE LOCOMOTIVE

DATA

Weights —Total.....	408,000 Lb.
On Drivers.....	300,000 Lb.
Per Driving Axle.....	75,000 Lb.
Ratings —One Hour, Forced Vent. T. E.....	59,000 Lb.
335 Volts per Motor	Speed.... 21.0 M.p.h.
	Hp..... 3,300
Continuous	T. E..... 50,000 Lb.
	Speed.... 23.0 M.p.h.
	Hp..... 3,070
Maximum Tractive Effort, 33 $\frac{1}{3}$ % Adhesion,	
Limited by Motor Capacity.....	100,000 Lb.
Tractive Effort, 25% Adhesion.....	75,000 Lb.
Maximum Speed.....	35 M.p.h.
Number & Nominal Rating of Motors.....	4—825 Hp.
Gear Ratio.....	30:118
Driver Diameter.....	80 In.
Trolley Voltage.....	11,000 A-C.
Road No.....	3,930


GENERAL INFORMATION

This locomotive is the latest development in single-phase locomotives employing commutator type motors. It is intended to be used either in freight service or high speed passenger service, the change in speed being secured by changing the gear ratio. The data above applies to the locomotive when geared for freight service. With a 50:98 gear ratio, the locomotive has a continuous tractive effort rating of 25,000 lb. at 46 miles an hour and a maximum speed of 70 miles an hour.

The drive is by geared jack shaft and side rods, each jack shaft being driven by two motors. The jack shaft gear is of a new flexible type and two of the four pinions which mesh with each jack shaft are also flexible. The four driving wheels are in one rigid wheel base and the cab is rigidly mounted on the side frames.

The control of this locomotive is extremely simple. Acceleration is obtained by raising the motor voltage by means of taps on the main transformer. The low voltage taps may also be used for running when reduced speed is desired. The transformer is of the oil insulated forced-cooled type.

Westinghouse Electric & Manufacturing Company
East Pittsburgh, Penna.



PENNSYLVANIA RAILROAD

L-5 Type Locomotive

NORFOLK AND WESTERN RAILWAY

DATA

Weights —Total.....	828,000 Lb.
On Drivers.....	596,000 Lb.
Per Driving Axle.....	74,500 Lb.
Ratings —One Hour, 8 Pole, Forced	
Vent.....	T. E.....108,000 Lb.
	Speed.....14.1 M.p.h.
	Hp.....4,060
4 Pole,	T. E.....63,000 Lb.
	Speed.....28.3 M.p.h.
	Hp.....4,750
Continuous 8 Pole,	T. E.....90,000 Lb.
	Speed.....14.2 M.p.h.
	Hp.....3,400
4 Pole,	T. E.....52,500 Lb.
	Speed.....28.4 M.p.h.
	Hp.....4,000

Maximum Tractive Effort, 31.1% Adhesion,	
Limited by Motor Capacity.....	185,000 Lb.
Tractive Effort, 25% Adhesion.....	149,000 Lb.
Maximum Speed.....	38 M.p.h.
Number & Nominal Rating of Motors..	4—1,190 Hp. (4P)
Gear Ratio.....	21:100
Driver Diameter.....	62 In.
Trolley Voltage.....	11,000 A-C.
Road Nos.....	2512-2515


GENERAL INFORMATION

This locomotive consists of two coupled cabs, each cab having four driving axles in one rigid wheel base. The cab structure is mounted rigidly on the locomotive side frames which are of massive vanadium steel construction. The heavier parts of the electrical equipment are mounted on the cross ties which connect the side frames.

The locomotive is of the so-called split-phase type and is driven by three-phase induction motors which receive their power from a phase converter and main transformer. The motors have two windings which give constant running speeds of approximately 14 and 28 m.p.h. Regenerative braking is automatic at either speed. Smooth acceleration is obtained with a liquid rheostat of an improved type.

These locomotives are used to haul heavy coal trains over a profile which includes 5.28 miles of 1.7 percent grade. Two locomotives handle a 4,200 ton coal train up the grade.

Westinghouse Electric & Manufacturing Company
East Pittsburgh, Penna.



NORFOLK & WESTERN RAILWAY
414-Ton Freight Locomotive

NEW YORK, NEW HAVEN & HARTFORD RAILROAD PASSENGER LOCOMOTIVE

DATA


Weights —Total	350,000 Lb.
On Drivers	233,000 Lb.
Per Driving Axle	38, 830 Lb.
Ratings —One Hour, Forced Vent.	T. E.	18,000 Lb.
335 Volts per Motor	Speed	51 M.p.h.
	Hp.	2,460
Continuous	T. E.	12,540 Lb.
	Speed	61 M.p.h.
	Hp.	2,040
Maximum Tractive Effort, 20.4% Adhesion,		
Limited by Motor Capacity	47,520 Lb.
Maximum Speed	70 M.p.h.
Number & Nominal Rating of Motors	6 Twin 410 Hp.
Gear Ratio	27:87
Driver Diameter	63 In.
Trolley Voltage	11,000 A-C.
Road Nos.	0300-0304

GENERAL INFORMATION

Five of these locomotives have been in service since 1919 and twelve more have recently been delivered to the New Haven. These locomotives have six driving axles, each driven by a twin single-phase commutator type motor through gearing and a quill. They are used in fast passenger service between New York and New Haven and are capable of handling a 900-ton train in this service. Motors of the type used on these locomotives will run on either alternating or direct current and the control is arranged so that they can run into the Grand Central Station or over the Hell Gate Bridge, taking power from a third rail at 600 volts direct current. This increases the weight of the locomotive somewhat.

An oil fired steam boiler capable of producing 4,000 lb. of steam per hour at 100 lb. per sq. in. is supplied on all of the seventeen locomotives.

Westinghouse Electric & Manufacturing Company
East Pittsburgh, Penna.



NEW YORK, NEW HAVEN & HARTFORD RAILROAD

175-Ton Passenger Locomotive

NEW YORK, NEW HAVEN & HARTFORD RAILROAD FREIGHT LOCOMOTIVE


DATA

Weights —Total.....	219,500 Lb.
On Drivers.....	165,000 Lb.
Per Driving Axle.....	41,250 Lb.
Ratings —One Hour, Forced Vent. T. E.....	21,200 Lb.
330 Volts per Motor Speed....	28.5 M.p.h.
Hp.....	1,610
Continuous T. E.....	14,760 Lb.
Speed....	34 M.p.h.
Hp.....	1,336
Maximum Tractive Effort, 34.0% Adhesion, Limited by Motor Capacity.....	56,000 Lb.
Tractive Effort, 25% Adhesion.....	41,250 Lb.
Maximum Speed.....	45 M.p.h.
Number & Nominal Rating of Motors..	4 Twin 404 Hp.
Gear Ratio.....	17:97
Driver Diameter.....	63 In.
Trolley Voltage.....	11,000 A-C.
Road Nos.....	076-0111

GENERAL INFORMATION

This locomotive is a type well suited to freight service on a line having approximately level track. It can handle fifty-five 45-ton cars on level tangent track and, if longer trains are necessary, two units can be coupled together and operated as a single locomotive from one master controller. Each step of the master controller is an economical running position so that the locomotive has a very flexible control. The drive is by quill and gearing, similar to other New Haven locomotives. Twin commutator type motors, mounted directly above the driving axles are used. Thirty-six of these locomotives have been in use on the New Haven since 1912.

Westinghouse Electric & Manufacturing Company
East Pittsburgh, Penna.



NEW YORK, NEW HAVEN & HARTFORD RAILROAD

110-Ton Freight Locomotive

NEW YORK, NEW HAVEN & HARTFORD RAILROAD SWITCHER LOCOMOTIVE


DATA

Weights —Total.....	159,200 Lb.
On Drivers.....	159,200 Lb.
Per Driving Axle.....	39,800 Lb.
Ratings —One Hour, Forced Vent. T. E.....	23,200 Lb.
228 Volts per Motor	Speed....10.5 M.p.h.
	Hp.....652
Continuous	T. E.....14,400 Lb.
	Speed....13.5 M.p.h.
	Hp.....520
Maximum Tractive Effort, 29.0% Adhesion, Limited by Motor Capacity.....	46,000 Lb.
Tractive Effort, 25% Adhesion.....	39,800 Lb.
Maximum Speed.....	25 M.p.h.
Number & Nominal Rating of Motors.....	4—163 Hp.
Gear Ratio.....	17:101
Driver Diameter.....	63 In.
Trolley Voltage.....	11,000 A-C.
Road Nos.....	0201-0214

GENERAL INFORMATION

In many respects the New Haven operates the world's most comprehensive electrification in that it has all classes of service electrified. The switcher locomotives are of the steeple cab type with all the weight on the drivers. Each axle is driven through gearing and a quill by a single 25-cycle motor of the commutator type. It has double end control and low speed suitable for switching service. The two four-wheel trucks are articulated so that the tractive effort is transmitted through the truck frames rather than through the cab structure. This locomotive has proved in service to be a very satisfactory type.

Westinghouse Electric & Manufacturing Company
East Pittsburgh, Penna.



NEW YORK, NEW HAVEN & HARTFORD RAILROAD

80-Ton Switcher Locomotive

STANDARD 50-TON LOCOMOTIVE


DATA

Weights —Total.....	100,000 Lb.
On Drivers.....	100,000 Lb.
Per Driving Axle.....	25,000 Lb.
Ratings —One Hour, Short Field, T. E.....	12,600 Lb.
Natural Ventilation	Speed....14.9 M.p.h.
	Hp.....500
Continuous, Short Field T. E.....	9,400 Lb.
	Speed....16.2 M.p.h.
	Hp.....400
Maximum Tractive Effort, 36.4% Adhesion, Limited by Motor Capacity.....	36,400 Lb.
Tractive Effort, 25% Adhesion.....	25,000 Lb.
Maximum Speed.....	47 M.p.h.
Number & Nominal Rating of Motors.....	4—125 Hp.
Gear Ratio.....	17:60
Driver Diameter.....	36 In.
Trolley Voltage.....	1,500 D-C.

GENERAL INFORMATION

This locomotive is a standard unit built by the Westinghouse Company for light freight haulage and general purposes. The motors are standard slow speed direct current machines and the product of long experience in design. The locomotive can be arranged for 600, 750, 1,200 or 1,500-volt operation. The data above applies to 750 motor voltage which would be obtained with either 750 or 1,500 volts on the trolley wire. With operation on 600 or 1,200 volts, the speeds will be slightly less than 80 per cent of the speed with 750 volts per motor. If higher speeds are desired, the locomotive can be supplied with different windings in the motors.

Westinghouse Electric & Manufacturing Company
East Pittsburgh, Penna.



WESTINGHOUSE STANDARD 50-TON LOCOMOTIVE

Copyright June 1924 by W. E. & M. Co.

**Data on
Representative Modern
Steam Locomotives**

Model	Weight	Tractive Effort	Speed	Capacity
10000	100,000	25,000	15	100,000
10001	100,000	25,000	15	100,000
10002	100,000	25,000	15	100,000
10003	100,000	25,000	15	100,000
10004	100,000	25,000	15	100,000
10005	100,000	25,000	15	100,000
10006	100,000	25,000	15	100,000
10007	100,000	25,000	15	100,000
10008	100,000	25,000	15	100,000
10009	100,000	25,000	15	100,000
10010	100,000	25,000	15	100,000
10011	100,000	25,000	15	100,000
10012	100,000	25,000	15	100,000
10013	100,000	25,000	15	100,000
10014	100,000	25,000	15	100,000
10015	100,000	25,000	15	100,000
10016	100,000	25,000	15	100,000
10017	100,000	25,000	15	100,000
10018	100,000	25,000	15	100,000
10019	100,000	25,000	15	100,000
10020	100,000	25,000	15	100,000
10021	100,000	25,000	15	100,000
10022	100,000	25,000	15	100,000
10023	100,000	25,000	15	100,000
10024	100,000	25,000	15	100,000
10025	100,000	25,000	15	100,000
10026	100,000	25,000	15	100,000
10027	100,000	25,000	15	100,000
10028	100,000	25,000	15	100,000
10029	100,000	25,000	15	100,000
10030	100,000	25,000	15	100,000
10031	100,000	25,000	15	100,000
10032	100,000	25,000	15	100,000
10033	100,000	25,000	15	100,000
10034	100,000	25,000	15	100,000
10035	100,000	25,000	15	100,000
10036	100,000	25,000	15	100,000
10037	100,000	25,000	15	100,000
10038	100,000	25,000	15	100,000
10039	100,000	25,000	15	100,000
10040	100,000	25,000	15	100,000
10041	100,000	25,000	15	100,000
10042	100,000	25,000	15	100,000
10043	100,000	25,000	15	100,000
10044	100,000	25,000	15	100,000
10045	100,000	25,000	15	100,000
10046	100,000	25,000	15	100,000
10047	100,000	25,000	15	100,000
10048	100,000	25,000	15	100,000
10049	100,000	25,000	15	100,000
10050	100,000	25,000	15	100,000

DATA ON REPRESENTATIVE MODERN STEAM LOCOMOTIVES

Road	Manu- facturer	Wheel Arrange- ment	Cylinder Dimension		Total Evaporative Heating Surface Sq. Ft.	Tractive Effort 85%	Driver Diam. In.	Driving Wheel Base	Weight	
			Bore	Stroke					Total Eng. & Tend.	On Drivers
Virginian....	Am.	2-10-10-2	{ 30 48 }	32	8606	147200	56	50'-0''	898300	617000
C. & O.....	Am.	2-8-8-2	23	32	6447	103500	57	774000	491000
P.R.R.....	P.R.R.	2-8-8-0	30½	21	6656	135000	62	794000	540000
Virginian....	Am.	2-8-8-2	{ 25 39 }	32	6120	101300	57	42'-4''	740100	478000
N. & W.....	Bald.	2-8-8-2	{ 24.5 39 }	32	6308	104300	56	42'-1''	695000	470500
Reading.....	Bald.	2-8-8-2	{ 26 40 }	32	5747	98000	55½	39'-8''	630000	435200
Southern....	Bald.	2-8-8-2	{ 25 39 }	30	4993	84800	56	41'-1''	603000	374000
P.R.R.....	Bald.	0-8-8-0	{ 26 40 }	28	5030	100000	51	40'-1½''	650000	458140
N. & W.....	Bald.	2-6-6-2	{ 22 35 }	32	4771	67500	56	30'-6''	571000	341000
P.R.R.....	{ P.R.R. Bald. }	2-10-0	30½	32	4808	90400*	62	22'-8''	553400	341000
B. & O.....	Bald.	2-10-2	30	32	5270	84400	58	22'-4''	730000	347230
So. Pac.....	Bald.	2-10-2	29½	32	5103	71150	63½	22'-10''	621000	306000
Can. Nat... {	{ Mont. Loc. }	2-8-2	27	30	3551	54600	63	16'-6''	499900	227600
D. L. & W... {	{ Am. Loc. }	2-8-2	28	32	4418	67700	63	17'-0''	574100	271500
L. V.....	Am.	2-8-2	27	32	4009	63000	63	16'-6''	489500	239000
L. V.....	Bald.	2-8-2	27	30	4110	59000	63	16'-6''	477000	237900
Nickel Plate	Lima	2-8-2	26	30	3777	54700	63	16'-9''	506800	238100
Union Pacific	Am.	4-8-2	29	28	4974	54800	73	19'-6''	582800	230000
St. L. & S. F.	Bald.	4-8-2	28	28	4382	54100	69	18'-0''	584500	232100
Can. Nat... {	{ Can. Loc. }	4-8-2	26	30	4079	49600	73	19'-6''	577000	226770
Great North.	Bald.	4-8-2	29	28	5025	54830	73	19'-0''	617000	272000
N. Y. C.....	Am.	4-8-2	{ 3 25 }	28	5155	64700	69	18'-0''	634800	241500
Can. Pac... {	{ Mont. Loc. }	4-6-2	25	30	3530	42600	75	13'-2''	489000	181500
P.R.R.....	P.R.R.	4-6-0	24	28	2862	41330	68	14'-3''	413500	178000
Maine Centr'l	Lima	4-6-0	20	28	2005	30200	63	15'-0''	319600	136000

ELECTRIC LOCOMOTIVES OF NORTH AND SOUTH AMERICA

ELECTRIC LOCOMOTIVES OF NORTH & SOUTH AMERICA

RAILROAD	KEY NO.	SERIES NO.	YEAR OF SERVICE	CLASS OF SERVICE	MFG CO.	CLASS OF MOTOR	CONTACT CONDUCTOR	TYPE OF LOCO.	CLASSIFICATION BY WHEELS	DRIVING WHEELS		TRUCK WHEELS		ARTICULATED TRUCKS	WHEEL BASE	WEIGHTS - LBS.				DIMENSIONS			MOTORS	TRACTION EFFORT - LBS.					SPEED M.P.H.					HORSE POWER OF LOCOMOTIVE	MOTORS PER AXLE								
										NO.	DIA.	NO.	DIA.			TOTAL	TOTAL	ON DRIVERS	AV. PER DRIVING AXLE	MECH. PARTS	ELECT. PARTS	LENGTH OVER ALL		WIDTH OVER ALL	HEIGHT TO TOP OF BOILER	HEIGHT TO TOP OF TENDR	HEIGHT TO TOP OF CONTROL	NO.	TYPE	GEAR RATIO	ONE HOUR RATING WITH FORCED VENTILATION	% COEF. OF ADHESION	CONTINUOUS RATING WITH FORCED VENTILATION			% COEF. OF ADHESION	STARTING RATING WITH FORCED VENTILATION	% COEF. OF ADHESION	LIMITED BY MOTOR CAPACITY	ONE HOUR RATING	CONTINUOUS RATING	MAX. SAFE	ONE HOUR RATING
Baltimore & Ohio	1a	8-9	4	1903	G.E.	Frt	600	3 rd Rail	D.C.	080	8	42"	0	—	14'-6"	14'-6"	160,000	160,000	40,000	116,000	44,000	29'-7"	9'-2"	15'-8"	No	4	GE 63B	Gear	19:81	36,000	22.5	—	—	40,000	8.0	—	8.00	—	—	600	600		
Baltimore & Ohio	1b	11-12	2	1910	"	P+F	600	"	"	040-040	8	50"	0	—	Yes	9'-6"	27'-6"	185,000	185,000	46,250	119,000	66,000	39'-6"	10'-2"	14'-5"	No	4	GE 209A	"	24:78	25,000	13.5	12,800	6.9	46,250	16.4	19.6	4.5	11.00	670	600		
Baltimore & Ohio	1c	13-14	2	1912	"	"	600	"	"	040-040	8	50"	0	—	Yes	9'-6"	27'-6"	200,000	200,000	50,000	135,000	65,000	39'-6"	10'-2"	14'-5"	No	4	GE 209A	"	24:78	25,000	12.5	12,800	6.4	50,000	16.4	19.6	4.5	11.00	670	600		
Baltimore & Ohio	1d	15-16	2	1923	"	"	600	"	"	040-040	8	50"	0	—	Yes	9'-6"	27'-6"	200,000	240,000	60,000	175,000	65,000	39'-6"	10'-2"	14'-5"	No	4	GE 209A	"	24:78	25,000	10.4	12,800	5.3	60,000	16.4	19.6	4.5	11.00	670	600		
Bathlehem Chile Iron Mines	2	6-8	3	1920	G.E.	Frt	2400	5 th Rail Catenary	D.C.	040-040	8	52"	0	—	Yes	11'-0"	35'-6"	238,000	238,000	59,750	120,600	118,400	49'-6"	10'-0"	16'-7"	Yes	4	GE 253R	2 nd Gear	18:82	42,000	17.6	35,200	14.7	59,750	12.2	12.7	3.5	13.70	1190	1200		
Boston & Maine	3a	5000-4	5	1911	W. West	P+F	11,000	Catenary	A.C.	240-042	8	65"	4	42"	Yes	7'-0"	38'-6"	260,000	204,000	51,000	141,800	118,200	48'-5"	10'-3"	14'-5"	No	4	W403	"	22:91	18,480	9.1	18,000	8.8	51,000	72,000	25.0	25.5	37.5	12.32	12.24	342	342
Boston & Maine	3b	5005-6	2	1917	"	"	11,000	"	"	240-042	8	65"	4	42"	Yes	7'-0"	38'-6"	265,500	217,000	54,250	147,500	118,000	48'-0"	10'-1"	14'-0"	No	4	W403R	"	22:91	18,480	8.5	18,000	8.3	54,250	72,000	25.0	25.3	37.5	12.32	12.24	342	342
Butte, Anaconda & Pacific	4a	39-64	26	1913	G.E.	Frt	2400	Catenary	D.C.	040-040	8	48"	0	—	Yes	8'-8"	26'-0"	160,000	160,000	40,000	100,000	60,000	37'-4"	10'-0"	15'-6"	No	4	GE 229R	2 nd Gear	18:81	30,600	19.3	25,000	15.6	40,000	15.4	16.2	3.5	12.80	1090	1200		
Butte, Anaconda & Pacific	4b	65-6	2	1913	"	Pass	2400	"	"	040-040	8	48"	0	—	Yes	8'-8"	26'-0"	160,000	160,000	40,000	100,000	60,000	37'-4"	10'-0"	15'-6"	No	4	GE 229R	"	25:80	20,200	12.6	16,200	10.1	40,000	23.4	24.6	5.0	12.80	1090	1200		
Canadian Natl (Mt. Royal Tun.)	5	600-5	6	1918	G.E.	P+F	2400	Catenary	D.C.	040-040	8	46"	0	—	Yes	8'-8"	26'-0"	166,000	166,000	41,500	102,540	63,460	37'-4"	10'-0"	15'-6"	No	4	GE 229R	2 nd Gear	25:83	20,200	12.2	16,200	9.8	41,500	23.4	24.6	5.0	12.80	1090	1200		
Chicago, Milwaukee & St. Paul	6a	1030-3	4	1917	G.E.	Smith	3000	Catenary	D.C.	040-040	8	40"	0	—	No	8'-0"	30'-4"	143,200	143,200	55,800	80,900	62,300	41'-5"	10'-1"	16'-8"	No	4	GE 253R	Gear	17:64	21,400	15.0	14,000	9.8	35,800	11.5	12.8	3.5	6.60	4.80	1500	1500	
Chicago, Milwaukee & St. Paul	6b	0200-41	42	1916	"	Frt	3000	"	"	4-0-0-0-0	16	52"	8	36"	Yes	10'-6"	102'-8"	576,000	450,000	56,250	328,000	248,000	112'-0"	10'-0"	16'-8"	Yes	8	GE 253	"	18:82	24,500	18.8	70,700	15.7	112,500	15.3	15.9	3.5	5.440	3000	1500		
Chicago, Milwaukee & St. Paul	6c	10250-4	5	1920	"	Pass	3000	"	"	2-0-2-0-2	24	44"	4	36"	Yes	13'-6"	67'-0"	521,200	457,800	38,150	286,550	234,650	76'-0"	10'-0"	16'-8"	Yes	12	GE 100	Gearless	—	48,500	10.6	42,000	9.2	114,450	27.1	28.4	9.0	35.00	32.00	1000	1000	
Chicago, Milwaukee & St. Paul	6d	10500	1	1920	"	Frt	3000	"	"	4-6-2-2-6-4	12	60"	12	36"	Yes	16'-9"	79'-10"	600,000	378,000	63,000	367,200	232,800	88'-7"	11'-0"	17'-0"	Yes	8	W348	Gearless	21:92	78,000	20.6	48,100	12.7	94,500	180,600	22.6	26.4	5.5	4.680	3400	750	
Chicago, Milwaukee & St. Paul	6e	10301-9	9	1920	"	Pass	3000	"	"	4-6-2-2-6-4	12	68"	12	36"	Yes	16'-9"	79'-10"	600,000	378,000	63,000	367,200	232,800	88'-7"	11'-0"	17'-0"	Yes	8	W348	"	24:89	66,000	17.5	40,800	10.8	94,500	153,000	26.7	31.2	6.5	4.680	3400	750	
Chilean State	7a	2801-6	6	1923	W. West	G. Pass	5000	Catenary	D.C.	260-052	12	42"	4	30"	Yes	14'-5"	48'-4"	259,800	210,000	35,000	153,600	104,200	58'-5"	10'-6"	14'-4"	Yes	6	W554R5	2 nd Gear	21:56	25,000	12.3	19,800	9.4	52,500	70,800	36.0	39.7	6.3	2.460	2040	1500	
Chilean State	7b	2501-11	11	1923	"	Locals	3000	"	"	040-040	8	42"	0	—	Yes	8'-4"	26'-0"	160,000	160,000	40,000	94,600	65,400	38'-9"	10'-1"	14'-2"	No	4	W354R5	"	21:56	17,200	10.8	13,200	8.3	40,000	47,200	36.0	39.7	5.6	1.640	1360	1500	
Chilean State	7c	2001-15	15	1923	"	Frt	3000	"	"	060-060	12	42"	0	—	Yes	13'-9"	37'-0"	230,000	230,000	38,500	140,000	90,000	49'-9"	10'-6"	14'-4"	Yes	6	W350B5	"	15:63	51,200	13.6	24,360	10.6	57,500	84,000	21.5	23.0	4.4	1.800	1500	1500	
Chilean State	7d	2301-7	7	1923	"	Smith	3000	"	"	040-040	8	42"	0	—	No	8'-6"	27'-4"	137,000	137,000	34,250	82,500	54,500	40'-0"	10'-6"	14'-2"	No	4	W350R2	Gear	16:63	23,000	16.8	11,000	8.0	34,250	56,000	10.5	12.8	3.5	1.640	380	1500	
Grand Trunk (St. Clair Tunnel)	9	2655-6	3	1908	W. West	P+F	3300	Catenary	A.C.	2 nd 060-060	12	62"	0	—	—	16'-0"	45'-5"	264,000	264,000	44,000	147,300	116,700	58'-11"	9'-8"	13'-3"	No	6	W157	Gear	16:85	37,800	14.3	24,600	9.5	66,000	96,000	16.2	19.4	3.0	16.32	12.72	280	280
Great Northern	10	5000-3	4	1909	G.E.	P+F	6600	Direct Suspension	A.C.	040-040	8	60"	0	—	Yes	11'-0"	31'-9"	230,000	230,000	57,500	121,000	109,000	44'-2"	10'-0"	15'-1"	Yes	4	GE 1506	2 nd Gear	19:81	38,000	16.5	34,800	15.1	57,500	15.1	15.2	3.0	15.00	1400	500		
Long Island	12	323	1	1917	West.	Frt	650	3 rd Rail	D.C.	040-040	8	55"	0	—	No	7'-2"	26'-1"	115,800	115,800	43,950	114,640	61,160	38'-8"	10'-1"	13'-6"	No	4	W98	Gear	22:70	23,200	13.2	15,440	8.8	44,800	21.2	26.7	5.6	12.00	1000	650		
Mexican	13	1001-10	10	1924	G.E.	P+F	3000	Catenary	D.C.	040-040	12	45"	0	—	Yes	9'-2"	40'-6"	308,000	308,000	51,300	173,000	135,000	52'-11"	10'-1"	15'-2"	Yes	6	GE 278	Gear	18:90	54,000	17.6	48,500	15.8	77,000	19.0	19.5	3.9	27.36	25.20	1500	1500	
Michigan Central	14a	7500-5	6	1909	G.E.	P+F	600	3 rd Rail	D.C.	040-040	8	48"	0	—	Yes	9'-6"	27'-6"	200,000	200,000	40,000	135,000	65,000	39'-6"	10'-2"	14'-8"	No	4	GE 209R	2 nd Gear	19:82	35,000	17.5	18,000	9.0	50,000	11.8	14.0	4.0	11.00	670	600		
Michigan Central	14b	7506-9	4	1914	"	"	600	"	"	040-040	8	48"	0	—	Yes	9'-6"	27'-6"	240,000	240,000	60,000	175,000	65,000	39'-6"	10'-2"	14'-8"	No	4	GE 209R	"	19:82	34,000	14.2	18,000	7.5	60,000	12.3	14.0	4.0	11.00	670	600		
New York Central	15a	1100-34	35	1906	G.E.	Pass	600	3 rd Rail	D.C.	484	8	44"	8	33"	—	15'-0"	32'-6"	227,700	140,900	35,225	167,700	60,000	38'-9"	10'-1"	14'-9"	No	4	GE 84	Gearless	—	21,000	14.9	5,000	3.6	35,225	38.5	60.0	8.0	2.200	800	600		
New York Central	15b	1355-46	12	1909	"	"	600	"	"	484	8	44"	8	36"	—	15'-0"	36'-0"	244,500	148,500	37,125	184,500	60,000	45'-0"	10'-1"	14'-6"	No	4	GE 84	"	—	21,000	14.1	5,000	3.4	37,125	38.5	60.0	8.0	2.200	800	600		
New York Central	15c	1147-56	10	1913	"	"	600	"	"	484	16	35"	0	—	Yes	5'-0"	45'-7"	237,000	237,000	29,625	165,000	74,000	53'-2"																				

Electric Locomotives of North and South America (Cont.)

ELECTRIC LOCOMOTIVES OF NORTH & SOUTH AMERICA

RAILROAD	KEY NO	SERIAL NO.	U.S. PATENT NO.	MFG. CO.	MFG. YR.	TYPE	CLASSIFICATION BY WHEELS	DRIVING WHEELS		TRAIL WHEELS		WHEEL BASE		WEIGHTS - LBS.				DIMENSIONS				MOTORS		TRACTION EFFORT - LBS.						SPEED MPH			HORSE POWER OF LOCOMOTIVE		VOLTS PER AXLE					
								NO.	DIA.	NO.	DIA.	FRONT	REAR	TOTAL	ON DRIVERS	AX PER DRIVING AXLE	MCHG PARTS	ELECT. PARTS	LENGTH OVER ALL	WIDTH OVER ALL	HEIGHT TO TOP OF CAB	HEIGHT TO TOP OF MOTOR	NO.	TYPE	GEAR RATIO	ONE HOUR RATING WITH FORCED VENTILATION	% COEFF. OF ADHESION	CONTINUOUS RATING WITH FORCED VENTILATION	% COEFF. OF ADHESION	STARTING RATING WITH FORCED VENTILATION	ADJUSTED RATING WITH FORCED VENTILATION	LIMITED BY MOTOR CAPACITY	ONE HOUR RATING	CONTINUOUS RATING		MAX. SAFE	ONE HOUR RATING WITH FORCED VENTILATION	CONTINUOUS RATING WITH FORCED VENTILATION		
New York, New Haven & Hartford	16a	01-041	41	1901	GE	Pass	11000	4-0	52"	4	33	No	8-0	50-0	217,600	187,600	47,900	103,600	112,000	37'-7"	10'-2"	14'-3"	No	4	W130	—	8,000	4.8	3,200	3.1	—	19,600	39.0	73.0	88	12,600	1016	284		
	16b	068	1	1918	GE	Pass	11000	4-0	54"	8	55	Yes	10-0	54-0	291,000	194,000	48,500	172,000	119,000	62'-0"	10'-0"	14'-5"	No	4	GE1814	55:11	27,000	15.9	22,200	11.5	48,500	—	23,000	26.4	45	1800	1600	—		
	16c	069	1	1910	GE	Pass	11000	4-0	54"	8	55	No	11-0	59-0	252,000	176,000	44,000	131,500	120,500	46'-8"	10'-3"	14'-5"	No	8	W409R	22:92	15,600	8.9	10,940	6.2	—	41,200	58.8	46.3	54	1616	1356	330		
	16d	070	1	1910	GE	Pass	11000	4-0	54"	8	55	Yes	10-0	59-0	270,000	192,000	48,000	138,000	152,000	52'-0"	10'-3"	14'-6"	No	2	W406	Skated	—	16,800	8.7	12,000	6.2	—	36,000	29.0	34.3	61	1300	1100	310	
	16e	071	1	1910	GE	Pass	11000	4-0	54"	8	55	Yes	10-0	59-0	270,000	192,000	48,000	138,000	152,000	52'-0"	10'-3"	14'-6"	No	4	W403	Skated	34:79	10,400	5.6	10,120	5.4	—	40,400	51.5	53.0	67	1428	1432	380	
	16f	072	1	1911	GE	Pass	11000	4-0	54"	8	55	Yes	10-0	59-0	270,000	192,000	48,000	138,000	152,000	52'-0"	10'-3"	14'-6"	No	4	W403B	Skated	34:79	10,400	5.7	10,120	5.5	—	40,400	45.0	46.0	67	1248	1240	342	
	16g	073-075	3	1912-5	GE	Pass	11000	4-0	54"	8	55	Yes	10-0	59-0	270,000	192,000	48,000	138,000	152,000	52'-0"	10'-3"	14'-6"	No	8	W409C	—	22:92	15,600	8.6	10,840	6.0	—	41,200	38.8	46.3	62.5	1616	1356	330	
	16h	076-078	3	1912-3	GE	Pass	11000	4-0	54"	8	55	Yes	10-0	59-0	270,000	192,000	48,000	138,000	152,000	52'-0"	10'-3"	14'-6"	No	8	W409C	—	11:91	21,200	12.9	14,760	8.9	41,250	56,000	28.5	54.0	45	1616	1356	330	
	16i	079	1	1911	GE	Pass	11000	4-0	54"	8	55	Yes	10-0	59-0	270,000	192,000	48,000	138,000	152,000	52'-0"	10'-3"	14'-6"	No	4	W410	—	11:101	23,200	14.7	14,450	9.1	39,800	46,000	8.1	11.4	25	500	440	190	
	16j	080-084	5	1912	GE	Pass	11000	4-0	54"	8	55	Yes	10-0	59-0	270,000	192,000	48,000	138,000	152,000	52'-0"	10'-3"	14'-6"	No	4	W410	—	11:101	23,200	14.6	14,400	9.1	39,800	46,000	10.5	13.5	25	652	520	228	
	16k	085	1	1912	GE	Pass	11000	4-0	54"	8	55	Yes	10-0	59-0	270,000	192,000	48,000	138,000	152,000	52'-0"	10'-3"	14'-6"	No	4	W410	—	11:101	23,200	15.0	14,400	9.3	38,700	46,000	10.5	13.5	25	652	520	228	
	16l	086-088	3	1912-3	GE	Pass	11000	4-0	54"	8	55	Yes	10-0	59-0	270,000	192,000	48,000	138,000	152,000	52'-0"	10'-3"	14'-6"	No	12	W409C	—	27:81	18,000	7.7	12,540	5.4	—	47,520	51.0	61.0	70	2460	2040	335	
	16m	089-16	12	1923-4	GE	Pass	11000	4-0	54"	8	55	Yes	10-0	59-0	270,000	192,000	48,000	138,000	152,000	52'-0"	10'-3"	14'-6"	No	12	W409C	—	25:89	19,260	8.0	13,080	5.5	—	52,500	48.0	58.8	70	2508	2052	349	
	New York, Westchester & Boston	17	501	1	1912	GE	Pass	11000	4-0	54"	8	55	Yes	10-0	59-0	270,000	192,000	48,000	138,000	152,000	52'-0"	10'-3"	14'-6"	No	4	W410	Skated	11:101	23,200	14.6	14,400	9.1	39,800	46,000	10.5	13.5	25	652	520	228
		18a	2506-11	12	1915	GE	Pass	11000	4-0	54"	8	55	Yes	10-0	59-0	270,000	192,000	48,000	138,000	152,000	52'-0"	10'-3"	14'-6"	Yes	4	W410R	Skated	16:85	24,800	14.4	14,400	9.1	125,000	14.5	14.4	38	3200	3200	725	
	Norfolk & Western	18b	2512-15	4	1924	GE	Pass	11000	4-0	54"	8	55	Yes	10-0	59-0	270,000	192,000	48,000	138,000	152,000	52'-0"	10'-3"	14'-6"	Yes	4	W412	Skated	21:100	28,500	18.1	18,500	11.5	143,000	18.5	18.4	38	4960	3600	1150	
19a		3931	1	1917	GE	Pass	11000	4-0	54"	8	55	Yes	10-0	59-0	270,000	192,000	48,000	138,000	152,000	52'-0"	10'-3"	14'-6"	Yes	4	W415	Skated	21:106	28,000	20.0	17,000	16.6	110,000	140,000	20.4	20.5	35	4800	4000	850	
Pennsylvania System	19b	3950	1	1924	GE	Pass	11000	4-0	54"	8	55	Yes	10-0	59-0	270,000	192,000	48,000	138,000	152,000	52'-0"	10'-3"	14'-6"	No	4	W415	Skated	30:118	35,000	19.7	20,000	16.3	75,000	100,000	21.0	23.0	55	3300	3070	335	
	19c																																							
	19d	32-3	2	1910	GE	Pass	600	3-0	44"	8	36"	Yes	7-2	55-11"	332,000	208,000	52,000	205,000	127,000	64-11"	10'-7 1/2"	14-8 1/2"	No	2	W315	Skated	—	11,700	8.5	10,150	5.2	52,000	52,300	11.5	11.8	80	2130	1570	600	
	19e	10-31	22	1910	GE	Pass	600	3-0	44"	8	36"	Yes	7-2	55-11"	313,000	199,000	49,750	194,000	119,000	64-11"	11'-2 1/2"	14-8 1/2"	No	2	W315	Skated	—	16,700	8.4	10,150	5.1	—	49,400	47.8	50.0	80	2130	1570	600	
	19f	34-42	9	1911	GE	Pass	600	3-0	44"	8	36"	Yes	7-2	55-11"	319,000	203,000	50,750	202,500	116,700	64-11"	11'-2 1/2"	14-8 1/2"	No	2	W315	Skated	—	16,700	8.2	10,150	5.0	—	49,400	47.8	50.0	80	2130	1570	600	
19g	3951	1	1910	GE	Pass	600	3-0	44"	8	36"	Yes	8-6	26-11"	195,140	195,140	48,785	100,000	95,140	38-8"	10'-1 1/2"	14-6 1/2"	No	2	W315	Skated	—	19,820	10.1	10,940	5.6	—	38,500	11.9	14.3	40	1630	1423	300		
Paulista (South America)	20a	208-11	4	1921	GE	Pass	5000	4-0	44"	8	42"	Yes	7-9	46-0"	240,000	160,000	40,000	158,900	81,100	55'-0"	10'-1 1/2"	14-5"	Yes	4	GE267R	Skated	30:70	15,600	9.8	14,720	9.2	40,000	—	40.5	41.5	60	1680	1600	1500	
	20b	200-7	8	1921	GE	Pass	3000	4-0	44"	8	42"	Yes	8-8	22-0"	200,000	200,000	50,000	118,000	61,200	39'-2"	10'-1 1/2"	14-5"	Yes	4	GE267R	Skated	18:82	30,600	15.5	28,000	14.4	50,000	—	20.8	21.0	34	1680	1600	1500	
	20c	212-5	2	1921	GE	Pass	3000	4-0	44"	8	42"	Yes	8-4	41-2"	283,000	205,800	51,450	166,800	117,000	57'-11"	10'-7"	14-10"	Yes	4	W351	Skated	23:86	20,950	10.0	14,240	6.9	51,430	54,400	42.8	47.2	65	2400	1800	1500	
	20d	214-5	2	1921	GE	Pass	3000	4-0	44"	8	42"	Yes	14-0	37-0"	234,000	234,000	39,050	145,450	88,850	50'-2"	10'-8 1/2"	14-10"	Yes	6	W350	Skated	16:63	52,400	15.8	21,600	9.2	58,575	82,800	20.8	23.4	42	1800	1350	1500	
	20e			1924	GE	Pass	3000	4-0	44"	8	42"	No	—	—	140,000	140,000	35,000	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—		



(1) Without forced ventilation (2) Includes steam heating equipment (3) Short field ratings (4) Motors series parallel (5) 500V ratings (6) Continuous rating 120°C rise

TRAIN RESISTANCE

The summation of the forces opposed to the motion of a train at constant speed on straight level track is known as train resistance. It is usually expressed in pounds per ton of train weight. Train resistance includes all losses in bearings, losses due to rolling friction, bedding rails, flange friction and wind resistance. All of these variables depend on the condition of bearings, design of trucks, condition of the road-bed, shape and cross section of the cars, so that tests to furnish accurate data must be sufficiently comprehensive to eliminate errors due to purely local conditions. Various tests have been made in the past to secure consistent and accurate data. The component parts of train resistance have been studied and formulas developed covering them as well as the whole. In general, it may be said that train resistance expressed in pounds per ton varies with the speed and with the weight of the rolling equipment.

Although formulas for train resistance are available in a variety of forms, it is common practice to obtain train resistance values from curves. Very complete tests have been made by the University of Illinois on train resistance for both passenger and freight trains. These tests are fully described in bulletins Nos. 43 and 110. Inside are reprinted the curves which were drawn up as a result of these tests. These curves do not include locomotive resistance. A fair average value for this is 15 lb. per ton.

(See Tables Inside)



**Industrial
Lighting
Section**

(Including Sheets 14 to 20)

Westinghouse Electric & Manufacturing Company
East Pittsburgh, Penna.

S. P. 1707

6-24

Printed in U. S. A.

INDUSTRIAL LIGHTING

The great progress made in industrial lighting during the last few years has been due not only to the demand for increased production, savings in operation and betterment of working conditions, but has been made possible by improvements in lamps and equipment and in methods of installation. Among the advantages of good factory lighting are:

1. Increased production for the same labor cost.
2. Greater accuracy in workmanship.
3. Decrease in spoilage.
4. Reduction of accidents.
5. Improved order and cleanliness in the plant.
6. Easier supervision of men.
7. Better working and living conditions.
8. Less eye strain and physical fatigue.
9. Greater contentment of men, reducing labor turnover.
10. Lowered compensation insurance rates.

Requirements for Good Lighting

In the design of an adequate system for an industrial plant the following requirements must be met:

1. A steady light of sufficient intensity on all working surfaces.
2. A comparable intensity of light on adjacent areas and on the walls.
3. Light of a color and spectral character suited to the purpose for which it is employed.
4. Freedom from glare and from glaring reflections.
5. Light so directed and diffused as to avoid objectionable shadows or contrast of intensity.
6. A system which is simple, reliable, easy to maintain and reasonable in initial and operating costs.

Modern reflectors and Mazda C lamps are universally applicable to the vast diversity of conditions arising in the demand for good lighting of industrial plants.

Types of Factory Lighting

The principal types of illumination used in industrial plants are: (1) General lighting, secured by a system giving uniform intensity throughout a shop without regard to machines or work; it approaches more nearly "daylight" conditions than any other system. (2) Localized lighting,

Westinghouse Electric & Manufacturing Company
East Pittsburgh, Penna.

S. P. 1707
Sheet 14

6-24

Printed in U. S. A.

secured by single units suspended over individual working planes. (3) General and localized lighting, a combination of the first two types. (4) Modified lighting, secured by suspending lighting units so that the maximum amount of illumination will be received on the most important working planes.

ILLUMINATING CALCULATIONS

Although the installation of every lighting system involves individual problems which must be studied to obtain the best results, the procedure in designing a general lighting system has been very well standardized. It may be divided into the following steps:

1. **Selection of the desirable intensity of illumination on the working plane.** This depends upon the character of the work to be done. Table II gives recommended values for various classes of work. It should be remembered, however, that increased illumination will result in increased production. This holds true even above the figures given as desirable intensities.

2. **Determination of the utilization constant.** Part of the light emitted by the lamp does not reach the working plane but is absorbed by the reflecting surfaces, walls, and ceiling. The amount depends upon the type of fixture, the color of the surroundings, and the proportions of the room. The ratio between the effective lumens and the total lumens is called the utilization constant. The values for the various conditions are given in Tables III and IV.

3. **Determination of the total quantity of light to be supplied by the lamp.** Use the values found above with the following formula:

$$\text{Total lumens} = \frac{\text{Area of room in sq. ft.} \times \text{intensity in ft. candles} \times \text{depreciation factor}}{\text{Utilization constant}}$$

(Depreciation factor: Under ordinary conditions the light output from open reflectors diminishes from 10 to 25 per cent after about four weeks, due to the collection of dust and dirt on the reflecting surface. Therefore, in designing an installation it is well to include a depreciation factor of 1.1 to 1.4.)

4. **Selection of suitable lighting unit.** The choice of lighting equipment best suited for a proposed installation should be made with regard to the requirements of good lighting as covered on the preceding page. The data given under "Selection of Reflector" gives the relative values of the various types of units with respect to the more important criteria.

Industrial Lighting (Cont.)

5. **Determination of number of lamps to be used and their location.** The area to be lighted should be divided as nearly as possible into equal squares and a lighting unit placed at the center of each square. The size of the squares depends upon the ceiling height, the division of the room by columns or ceiling beams into bays, and the extent to which shadows will be objectionable. The higher the ceiling the greater will be the allowable spacing between lighting units, and generally speaking, fewer units of larger size are preferable to a large number of smaller units. Not only are the larger lamps more efficient, but the expenses of wiring and maintenance are reduced. On the other hand a few large lamps will produce deep shadows, and the intensity of these shadows is decreased as the number of units is increased. The ideal number is the smallest that will give reasonably uniform lighting. The distribution of light from a lamp may be controlled to produce the same results with different types of reflectors if the proper ratio between mounting height and outlet spacing is observed. This relation is as follows: With the R L M standard dome type the maximum spacing of outlets is $1\frac{3}{4}$ times the mounting height; with the standard bowl type the maximum spacing of outlets is $1\frac{1}{4}$ times mounting height.

6. **Determination of size of lamps.** The total lumens required can now be divided by the number of outlets to obtain the lumens per lamp. From Table V, the lamp which gives nearest that amount of light may then be selected.

Planning a Specific Lighting Installation

Suppose the problem is to design a lighting system for a machine shop. The character of the work performed in the shop may be classified as medium grade, that is, there is no very fine work. Area of room 80 x 120 ft. or 9,600 sq. ft. with 12 ft. ceiling. Lower section of walls tan, ceiling and upper part of walls white.

1. The recommended foot-candle values for medium machine work vary from 6- to 12-foot candles, (Table II). Select 9-foot candles as an average.


2. Porcelain enameled steel reflectors are the most practical for factory lighting. In this particular case the R L M Standard Dome Reflector is recommended because of its sturdiness, medium cost and wide distribution of light. It will be desirable to use bowl enameled lamps because this coating reduces the apparent brightness of that portion of the bulb.

Westinghouse Electric & Manufacturing Company
East Pittsburgh, Penna.

S. P. 1707
Sheet 15

6-24

Printed in U. S. A.



Correct layout for the problem

3. The Utilization Constant (Tables III & IV) for the R L M Standard Dome Reflector and bowl enameled lamp in a room with light ceilings and walls will be 0.54. An allowance of 15 percent must be made for depreciation in light output due to the unavoidable collection of dust between cleaning periods and gradual aging of the lamp. Assuming this allowance of 15 percent a depreciation factor of 0.85 should be used.

4. Total lumens necessary.

$$\frac{80 \times 120 \text{ (sq. ft.)} \times 9}{.54 \times .85} = 188,235$$

5. From Table I, it will be seen that four outlets per bay are necessary with a 12-foot ceiling, if uniform illumination is to be obtained. With twenty-four bays there will be a total of ninety-six outlets.

6. Dividing the total numbers of lumens required by the number of outlets gives the lumens which each lamp must supply.

$$\frac{188,235}{96} = 1,960$$

Table V shows that a 150 watt Mazda C lamp generates 2,100 lumens and, therefore, is the proper size for this installation.

7. To determine the correct mounting height refer to Table I. Columns three and one show that for a spacing of 10 feet the unit should be mounted 7 feet 6 inches above the working plane or 10 feet above the floor.

Industrial Lighting (Cont.)

TABLE I
SPACING AND MOUNTING HEIGHT

Direct Lighting Units, Including Semi-enclosing and Totally Enclosing Units				
Mounting Height of Unit		Recommended Spacing Between Outlets	Recommended Distance Between Outlets and Sidewalls	
Above Plane of Work	Above Floor*		In Usual Locations where Aisles and Storage are Next to Wall	In Office or Where Work Benches are Next to Wall
4	6½	6	3	2
6	8½	9	4½	3
8	10½	12	6	4
10	12½	15	7½	5
12	14½	18	9	6
14	16½	21	10½	7
16	18½	24	12	8
20	22½	30	15	10
24	26½	36	18	12
30	32½	45	22½	15
40	42½	60	30	20

Semi and Totally Indirect Lighting Units

Ceiling Height		Recommended Spacing Between Outlets	Recommended Distance Between Outlets and Sidewalls		Suspension Distance to Top of Reflector †
Above Plane of Work	Above Floor*		In Usual Locations Where Aisles and Storage are Next to Wall	In Offices or Where Work Benches are Next to Wall	
5	7½	7½	3½	2½	1½
7	9½	10½	5	3½	1¾
9	11½	13½	6½	4½	2¼
11	13½	16½	8	5½	2¾
13	15½	19½	9½	6½	3¼
15	17½	22½	11	7½	3¾
18	20½	27	13½	9	4½
24	26½	36	18	12	6
30	32½	45	22½	15	7½
40	42½	60	30	20	10

*Plane of work assumed to be 2½ feet above floor. When the plane of work is higher or lower than 2½ feet above floor, neglect this column and work from the first column.

†Suspension distances in table are based on best distribution of light and efficiency of utilization for standard units. In some installations other considerations may require a different suspension distance.

Westinghouse Electric & Manufacturing Company
East Pittsburgh, Penna.

Copyright June 1924 by W. E. & M. Co.

TABLE II

Present Standards of Desirable Illumination for Various Classes of Service
Industries Classified Alphabetically

Industry or Place	Foot-candles Range
Aisles in Factories	1 - 2
Assembling of Manufactured Articles:	
Rough	3 - 6
Medium	5 - 10
Fine	8 - 16
Extra Fine	10 - 50
Boilers, Engine Rooms and Power Houses:	
Boilers, Coal and Ash Handling, Storage Battery Rooms	2 - 4
Auxiliary Equipment, Oil Switches and Transformers	3 - 6
Switchboards, Engines, Generators, Blowers and Compressors	4 - 8
Carpenter Shop (See Woodworking)	
Cars:	
Baggage	3 - 6
Day Coach, Subway	4 - 6
Dining	4 - 8
Mail	6 - 12
Pullman	4 - 8
Street Railway	4 - 8
Coal Breaking and Washing, Screening	2 - 4
Construction, General:	
Indoor	2 - 4
Outdoor (Rough)	0.5 - 2
Depot:	
Baggage Room	3 - 6
Train Sheds, Concourse	2 - 5
Waiting Room	3 - 6
Drafting	10 - 20
Electric Manufacturing:	
Storage Battery, Molding of Grids	4 - 8
Coil and Armature Winding, Mica Working, Insulating, Molding, Wire Insulating	8 - 16
Lamp Manufacturing (Exclusive of Mounting)	5 - 20
Erecting	2 - 6
Forge Shops and Welding:	
Rough Forging and Welding	4 - 8
Fine Welding	6 - 12

Industrial Lighting (Cont.)

TABLE II (Cont.)

Industry or Place	Foot-candles Range
Foundries:	
Charging Floor, Tumbling, Cleaning, Pouring and Shaking Out	3 - 6
Rough Molding and Core Making	4 - 8
Fine Molding and Core Making	6 - 12
Halls, Passageways in Interiors	1 - 3
Inspecting:	
Rough	4 - 8
Medium	6 - 12
Fine	10 - 20
Extra Fine	15 - 50
Lavatories	2 - 5
Locker Rooms	2 - 4
Machine Shops:	
Rough Bench and Machine Work	4 - 8
Medium Bench and Machine Work, Ordinary Automatic Machines, Rough Grinding, Medium Buffing and Polishing	6 - 12
Fine Bench and Machine Work, Fine Automatic Machines, Medium Grinding, Fine Buffing and Polishing	8 - 16
Extra Fine Bench and Machine Work, Small Instrument Assembling	10 - 50
Office:	
File Room	3 - 6
Desk	8 - 10
General	6 - 10
Vault (Safe)	4 - 6
Vault (Storage)	2 - 4
Paint Shops:	
Firing, Dipping and Spraying	3 - 6
Rubbing, Hand Painting and Finishing (Ordinary)	5 - 10
Hand Painting and Finishing (Fine)	8 - 16
Hand Painting and Finishing (Extra fine) (Automobile Bodies, Piano Cases, etc.)	10 - 50
Power House	4 - 6
Railway Station:	
Waiting Room	3 - 6
Ticket Offices, etc., (See Offices)	6 - 12
Rest Room, Smoking Room, etc.	3 - 6
Baggage Room	3 - 6
Concourse	3 - 6
Train Platform	2 - 4
Receiving and Shipping	3 - 6

Copyright June 1924 by W. E. & M. Co.

TABLE H (Cont.)

Industry or Place	Foot-candles Range
Roadways and Yard Thoroughfares.....	0.1 - 0.5
Shafting Pulleys and Mechanical Transmissions.....	1 - 3
Sheet Metal Works:	
Miscellaneous Machines, Ordinary Bench Work, Punch Presses, Shears, Stamps, Welders, Spinning, Fine Bench Work..	5 - 12
Tin Plate Inspection.....	10 - 20
Steel and Iron Mills, Bar, Sheet and Wire Products:	
Soaking Pits and Reheating Furnaces....	1 - 3
Charging and Casting Floors.....	3 - 6
Muck and Heavy Rolling, Shearing (Rough by Gauge), Pickling and Cleaning.....	3 - 6
Automatic Machines, Rod, Light and Cold Rolling, Wire Drawing, Shearing (Fine by Line).....	5 - 10
Plate Inspection.....	10 - 20
Stone Crushing and Screening:	
Belt Conveyor Tubes, Main Line Shafting Spaces, Chute Rooms, Inside of Bins...	1 - 2
Primary Breaker Room, Auxiliary Breakers under Bins.....	2 - 4
Screen Rooms.....	3 - 6
Storage and Stock Rooms:	
Rough, no Reading of Labels.....	1 - 3
Medium.....	3 - 6
Fine.....	4 - 8
Structural Steel Fabrication.....	4 - 8
Telegraph Operating.....	4 - 12
Telephone:	
Manual Exchanges.....	3 - 6
Automatic Exchanges.....	6 - 12
Warehouse.....	1 - 2
Wharf:	
Freight.....	1 - 3
Passenger.....	1 - 3
Woodworking:	
Rough Sawing (Saw Mills) Bench Work (Rough).....	3 - 6
Sizing, Planing, Rough Sanding, Machine Woodworking (Medium), Bench Work (Medium), Gluing and Veneering, Cooperage.....	5 - 10
Machine Woodworking (Fine), Bench Work (Fine), Fine Sanding and Finishing.....	6 - 12

Copyright June 1924 by W. E. & M. Co.

Industrial Lighting (Cont.)

SELECTION OF REFLECTOR

Various lighting units are rated in accordance with seven fundamentals, illustrated on the following page. The importance of these criteria is different for different classes of work. It must be emphasized that the relative importance of the various criteria should be carefully weighed with respect to the particular problem at hand. For instance, in an office the criteria would rank in importance: (1) direct glare; (2) reflected glare; (3) shadows; (4) efficiency based upon illumination on horizontal; (5) maintenance; (6) vertical illumination. On the other hand, where lamps are to be hung above a crane in a foundry, the order of importance would be: (1) efficiency based upon illumination on horizontal; (2) vertical illumination; (3) maintenance; (4) shadows; (5) direct glare; (6) reflected glare.

In the chart the best rating given is A, which denotes the highest degree of excellence, while D, the lowest, indicates that an installation of units so rated in any particular, will very likely prove unsatisfactory in an installation where this factor is important. The ratings B and C, while indicating a result not equal to A, are decidedly superior to rating D. In other words a rating B or C in certain respects does not disqualify a unit provided that in the essential requirements of a given location, the unit is rated A or B.

A+ } —Excellent B+ } —Good C } —Fair D —Very Bad
 A } B } C- }
 A- }

No.	Lighting Unit	Efficiency		Appearance of Room	Direct Glare	Reflected Glare	Shadows	Maintenance
		Horizontal	Vertical					
1	R L M Dome Type with Clear Lamp	A+	B+	C+	C	D	C+	A+
2	R L M Dome Type with Bowl Enamelled Lamp	A-	B	B	B+	B	B+	A-
3	Luminous Top R L M Dome Type with Clear Lamp	B	C+	A-	A-	B	B+	B
4	Standard Bowl Type with Clear Lamp	B+	B-	C	C+	D	C	A

Westinghouse Electric & Manufacturing Company
 East Pittsburgh, Penna.



Illumination on Horizontal Surfaces is a prime requisite in offices, drafting rooms and those shops where the problem is to provide the best illumination for sustained vision of flat surfaces on the horizontal or slightly oblique planes in which papers, books and other flat objects are usually examined.



Illumination on Vertical Surfaces of work or machine parts is fully as important as the lighting of the surface in the horizontal plane. In a consideration of the amount of light necessary for factory illumination, the criterion must be the intensity on all working surfaces whether vertical, horizontal or oblique.



Favorable Appearance of Lighted Room refers only to the general or casual effect produced by the complete system, and is not intended to rate the unit as to satisfaction from the standpoint of good vision or freedom from fatigue.



Direct Glare is the most frequent and serious cause of bad lighting. It results among other things from unshaded or inadequately shaded light sources located within the field of vision, or from too great a contrast between the bright light source and a dark background or adjacent surfaces. Glare should be avoided by the use of proper reflecting and diffusing equipment.



Reflected Glare from polished working surfaces is particularly annoying because of the necessity of directing the eyes toward those surfaces, and further, because the eyes are by nature especially sensitive to light rays from below. The harmful effects of this specular reflection can be minimized by properly shielding from below or diffusing the source.



Shadows, that is, difference in brightness of surfaces, are essential in observing objects in their three dimensions, but are of little or no value in the observation of flat surfaces. Where shadows are desirable, they should be soft and luminous, not so sharp and dense as to confuse the object with its shadow.



Maintenance depends upon the contour of the reflector, construction of fixture, and condition of ceiling. The rating is based upon the likelihood of breakage, the labor involved in maintaining the units at comparable degrees of efficiency, and indication given of need of cleaning.

Industrial Lighting (Cont.)

Utilization Constant

The Utilization Constant for a certain reflector is dependent upon the color of walls and ceilings and upon the proportions of the room, or room index.

The Room Index of a square room is equal to the width of the room divided by 2 times the mounting height above the working plane, i.e.:

$$\text{Room Index} = \frac{\text{width of room}}{2 \times \text{mounting height}}$$

For rooms of dimensions different from those in the table use the nearest available figure.

The utilization constant of rectangular rooms is equal to the constant for a square room of the narrow dimension plus one third of the difference between the constant for a square room of the long dimension and the constant for a square room of the narrow dimension.

For instance, to find the constant for an installation of R L M Dome Reflectors with Bowl Enameled lamps in a room 80 ft. x 160 ft., mounting height, 20 ft., light-colored ceiling, medium-light walls, follow the rule and you have:

For a room 80 ft. square. Room index = 2.0. From Table IV Utilization Constant = .50

For a room 160 ft. square. Room index = 4.0. From Table IV Utilization Constant = .58

For a room 80 ft. x 160 ft. From above rule Utilization Constant = .50 + 1/3 (.58 - .50) = .53





**TABLE III
ROOM INDEX OF A SQUARE ROOM**

		Mounting Height Above Working Plane in Feet															
		4	5	6	7	8	9	10	12	14	16	18	20	24	30	40	
Width of Room in Feet	8	1.0	.8	.6	.6	.6	.5										
	10	1.25	1.0	.8	.8	.6	.6	.5									
	12	1.5	1.25	1.0	.8	.8	.5	.5									
	14	1.5	1.5	1.25	1.0	.8	.8	.6	.6								
	16	2.0	1.5	1.25	1.25	1.0	.8	.8	.6	.6	.6						
	18	2.0	2.0	1.5	1.25	1.0	1.0	.8	.8	.6	.6	.6					
	20	2.5	2.0	1.5	1.5	1.25	1.0	1.0	.8	.8	.6	.8	.6				
	22	2.5	2.0	2.0	1.5	1.25	1.25	1.0	1.0	.8	.6	.8	.6				
	24	3.0	2.5	2.0	1.5	1.5	1.25	1.25	1.0	.8	.8	.8	.6	.6			
	26	3.0	3.0	2.0	2.0	1.5	1.5	1.25	1.0	.8	.8	1.0	.6	.6			
	28	3.0	3.0	2.5	2.0	1.5	1.5	1.5	1.25	1.0	.8	1.0	.6	.6			
	30	4.0	3.0	2.5	2.0	2.0	1.5	1.5	1.25	1.0	1.0	1.0	.8	.6	.6		
	35	4.0	3.0	3.0	2.5	2.0	2.0	1.5	1.25	1.25	1.0	1.25	.8	.8	.6		
	40	5.0	4.0	3.0	3.0	2.5	2.0	2.0	1.5	1.5	1.25	1.5	1.0	.8	.8	.6	
	45	5.0	4.0	4.0	3.0	3.0	2.5	2.0	2.0	1.5	1.5	1.5	1.0	1.0	.8	.6	
	50	5.0	5.0	4.0	4.0	3.0	3.0	2.5	2.0	2.0	2.5	2.0	1.25	1.0	.8	.6	
60	5.0	5.0	5.0	4.0	4.0	3.0	3.0	2.5	2.0	2.0	2.0	1.5	1.25	1.0	.8		
70	5.0	5.0	5.0	5.0	4.0	4.0	3.0	3.0	2.5	2.0	2.0	1.5	1.5	1.25	.8		
80	5.0	5.0	5.0	5.0	5.0	4.0	4.0	3.0	3.0	2.5	3.0	2.0	1.5	1.25	1.0		
100	5.0	5.0	5.0	5.0	5.0	5.0	5.0	4.0	4.0	3.0	4.0	2.5	2.0	1.5	1.25		
120	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	4.0	4.0	4.0	3.0	2.5	2.0	1.5		

Westinghouse Electric & Manufacturing Company
East Pittsburgh, Penna.

Copyright June 1924 by W. E. & M. Co.

TABLE IV
Utilization Constants

Color Reflection Factor	Ceiling		Very Light (70%)			Medium (50%)			Fairly Dark (30%)										
	Walls	Fairly Light 80%	Fairly Dark 30%	Very Dark 10%	Fairly Light 80%	Fairly Dark 30%	Very Dark 10%	Fairly Light 80%	Fairly Dark 30%	Very Dark 10%									
											Room Index	Utilization Constants							
RLM DOME  Clear Lamp 90 to 180°-0%	.6	.34	.29	.24	.34	.29	.24	.28	.24	.24	2.0	.58	.55	.51	.57	.54	.51	.53	.51
	.8	.42	.38	.34	.42	.37	.33	.37	.33	.33	2.5	.62	.59	.56	.61	.58	.56	.58	.56
	1.0	.46	.43	.39	.45	.42	.39	.42	.39	.39	3.	.64	.61	.58	.63	.60	.58	.60	.58
	1.25	.50	.47	.43	.49	.46	.43	.45	.43	.43	4.	.67	.65	.63	.66	.64	.62	.63	.61
	1.5	.53	.50	.46	.52	.49	.46	.48	.45	.45	5.	.69	.67	.65	.67	.66	.64	.65	.63
RLM DOME  Bowl Enameled Lamp 90 to 180°-0%	.6	.32	.28	.23	.32	.28	.23	.27	.23	.23	2.0	.52	.50	.48	.51	.49	.47	.49	.47
	.8	.40	.36	.34	.39	.35	.33	.35	.33	.33	2.5	.56	.54	.52	.55	.53	.51	.53	.51
	1.0	.43	.39	.37	.42	.39	.37	.39	.37	.37	3.	.57	.55	.53	.56	.54	.52	.54	.52
	1.25	.46	.43	.41	.45	.43	.41	.43	.41	.41	4.	.60	.58	.56	.59	.57	.55	.57	.55
	1.5	.48	.45	.43	.47	.45	.43	.45	.43	.43	5.	.61	.59	.57	.60	.58	.57	.58	.56
Luminous Top RLM Dome  Bowl Enameled Lamp 90 to 180°-8%	.6	.28	.25	.22	.27	.24	.22	.23	.21	.21	2.0	.47	.44	.42	.45	.43	.41	.41	.40
	.8	.34	.31	.29	.33	.30	.28	.30	.28	.28	2.5	.50	.47	.45	.48	.46	.44	.44	.43
	1.0	.38	.35	.33	.36	.34	.32	.33	.32	.32	3.	.51	.49	.47	.49	.47	.46	.46	.45
	1.25	.41	.38	.36	.39	.37	.35	.36	.35	.35	4.	.53	.51	.50	.51	.49	.48	.48	.47
	1.5	.43	.40	.38	.41	.39	.37	.38	.37	.37	5.	.55	.53	.51	.52	.50	.49	.49	.48
STD. BOWL  Clear Lamp 90 to 180°-0%	.6	.31	.26	.23	.30	.26	.23	.25	.23	.23	2.0	.51	.48	.45	.50	.47	.45	.47	.45
	.8	.38	.34	.31	.37	.34	.31	.33	.31	.31	2.5	.54	.51	.49	.53	.51	.49	.51	.49
	1.0	.41	.38	.35	.41	.38	.35	.37	.35	.35	3.	.56	.54	.51	.55	.53	.51	.53	.51
	1.25	.44	.41	.38	.44	.41	.38	.40	.38	.38	4.	.58	.56	.54	.57	.55	.54	.55	.53
	1.5	.47	.44	.41	.46	.43	.41	.43	.41	.41	5.	.60	.58	.56	.58	.57	.55	.56	.55

Copyright June 1934 by W. E. & M. Co.

Industrial Lighting (Cont.)

TABLE V

Total Lumens of Mazda Lamps for General Lighting Service

SIZE IN WATTS	110-120 Volts		Mazda C (Daylight)	220-250 Volts	
	Mazda B	Mazda C		Mazda B	Mazda C
10	82
15	131
25	238	195
40	404
50	510	500	455
60	612
75	...	885	602
100	...	1290	877	...	980
150	...	2145	1459
200	...	3060	2081	...	2460
300	...	4950	3366	...	4260
500	...	9050	6154	...	7850
750	...	14325	12525
1000	...	20000	17800

Diagram of Mounting Heights




Diagram showing the proper mounting heights of different types of reflectors when the spacing between lamps is 20 feet. For other spacings the mounting heights will be different because it is necessary to maintain the proper ratio between mounting heights and spacings.

Westinghouse Electric & Manufacturing Company
East Pittsburgh, Penna.

GENERAL DATA

Copper Wire Table

Size B & S Gauge	Diam. in Mils.	Lb. Per 1000 Ft.	Feet Per Lb.	Ohms Per 1000 Ft. 25° C	Ohms Per Mile 25° C
00	364.8	402.8	2.482	.0794	.419
0	324.9	319.5	3.130	.100	.528
1	289.3	253.3	3.947	.126	.665
2	257.6	200.9	4.977	.160	.845
3	229.4	159.3	6.276	.201	1.06
4	204.3	126.4	7.914	.254	1.34
5	181.9	100.2	9.980	.319	1.69
6	162.0	79.46	12.58	.403	2.13
7	144.3	63.02	15.87	.508	2.68
8	128.5	49.98	20.01	.640	3.38
9	114.4	39.63	25.23	.808	4.26
10	101.9	31.43	31.82	1.019	5.38
11	90.74	24.92	40.12	1.285	6.79
12	80.81	19.77	50.59	1.619	8.55
13	71.96	15.68	63.80	2.048	10.81
14	64.08	12.43	80.44	2.580	13.61
15	57.07	9.853	101.4	3.253	17.18
16	50.82	7.818	127.9	4.10	21.63
17	45.26	6.200	161.3	5.17	27.38
18	40.30	4.917	203.4	6.51	34.4
19	35.89	3.899	256.5	8.21	43.4
20	31.96	3.092	323.4	10.36	54.7
21	28.46	2.452	407.8	13.06	68.9
22	25.35	1.945	514.2	16.48	86.9
23	22.57	1.542	648.4	20.72	109.3
24	20.10	1.223	817.7	26.20	138.2
25	17.90	.9699	1.031	32.97	173.9
26	15.94	.7692	1.300	41.6	219.8


ARC WELDING AND CUTTING

For metallic electrode welding especially when portable equipment is desired the 200-ampere, single operator type is usually used.

When the welding work is brought to a central point multiple operator equipments may be used on account of the lesser cost of the equipment per welding circuit.

Multiple operator stationary or portable metallic or graphite electrode welding or graphite electrode cutting generators are available in capacities of 300, 500, 750 and 1000 amperes. One generator will serve power to a number of operators through suitable control panels depending upon the size of the generator and the amount of current to be used by each operator.

Copyright June 1924 by W. E. & M. Co.



Westinghouse Electric & Manufacturing Company
East Pittsburgh, Penna.

S. P. 1707
Sheet 21

6-24

Printed in U. S. A.

COST AND APPLICATION DATA
Approximate Cost of Cutting Steel or Cast Iron

Material Thickness	Current in Amperes	Time		Kw. Hours Per Foot	Power Cost Per Foot	Power and Labor Cost Per Foot
		Minutes Per Foot	Feet Per Hour			
1/4	400	.80	75	0.421	\$0.0084	\$0.0184
3/8	400	1.00	60	0.525	0.0105	0.0205
1/2	400	1.20	50	0.632	0.0126	0.0246
5/8	400	1.7	35	0.903	0.018	0.0351
3/4	400	3.0	20	1.58	0.0318	0.0618
1	600	3.75	16	2.92	0.0584	0.0959
1 1/8	600	4.3	14	3.34	0.0668	0.1096
2	600	6.7	9	5.2	0.1040	0.1706
4	600	17.0	3 1/2	13.35	0.2670	0.4385
6	800	30.0	2	31.0	0.620	0.920
8	800	40.0	1 1/2	41.3	0.827	1.227
10	800	60.0	1	62.0	1.240	1.840
12	800	80.0	3/4	82.7	1.653	2.453

Power at 2 cents per Kw.-hr. Labor at 60 cents per hour.
 Cost of cutting 1/4 in. rivets approximately \$1.10 per hundred.

Approximate Cost of Welding Steel Plate
 Butt Joint Beveled 45°

Plate Thickness	Current Used Amperes	Pounds of Wire Deposited Per Hour	Pounds of Wire Deposited Per Foot of Butt Joint	Feet of Butt Joint Welded Per Hour	Cost Per Hour		Cost Per Foot of Butt Joint Power, Wire and Labor
					Power	Power and Wire	
1/8	90	1.3	0.07	19	\$0.079	\$0.199	\$0.05
1/4	110	1.6	0.16	10	0.089	0.237	0.099
3/8	125	1.8	0.28	6.5	0.098	0.264	0.156
1/2	150	2.15	0.44	5	0.117	0.315	0.213
5/8	175	2.5	0.63	4	0.138	0.368	0.279
3/4	200	2.8	1.10	2.5	0.163	0.421	0.468
1	225	3.2	2.5	1.3	0.175	0.470	0.938
1 1/4	250	3.6	4.5	0.8	0.186	0.518	1.580

Lapped Joints Full Fillet Welds

Plate Thickness	Current Used Amperes	Pounds of Wire Deposited Per Hour	Pounds of Wire Deposited Per Foot of Lapp Joint	Feet of Lapp Joint Welded Per Hour	Cost Per Hour		Cost Per Foot of Lapp Joint Power, Wire and Labor
					Power	Power and Wire	
1/8	125	1.8	0.07	25	\$0.098	\$0.264	\$0.041
1/4	150	2.15	0.16	14	0.117	0.315	0.076
3/8	175	2.5	0.28	9	0.138	0.368	0.124
1/2	200	2.8	0.44	6.5	0.163	0.421	0.180
5/8	225	3.2	0.63	5	0.175	0.469	0.244
3/4	250	3.6	1.1	3.25	0.186	0.517	0.389
1	300	4.3	2.5	1.75	0.202	0.598	0.770
1 1/4	400	6.0	4.5	1.33	0.266	0.818	1.180

Power at 2 cents per Kw.-hr. Wire at 8 cents per pound. Labor at 75 cents per hour.

WHEEL LATHE EQUIPMENT

Direct current motors are as a rule, most satisfactory for wheel lathes because of their superior characteristics for speed adjustment, dynamic braking and rapid deceleration so desirable when hard spots are encountered. When direct current service is not available, alternating current motors equipped with wound rotors will give very satisfactory performance.

The modern control equipment for such service is a full magnetic type equipped with push buttons for starting, stopping and slowing down and a double throw knife switch for reversing the drive. When a D-C. motor is used a field rheostat is supplied for speed adjustment of the motor.

RECOMMENDED MOTOR RATINGS

Driving Wheel Lathes

SIZE OF MACHINE	HP. OF MOTORS	
	MAIN	TAIL STOCKS
51" x 108"	15	5
69" x 108"	20	8½
84" x 108"	25	8½
90" x 108"	35	8½
100" x 108"	50	8½

Car Wheel Lathes, Open Centre

SWING IN INCHES	HP. OF MOTORS	
	MAIN	TAIL STOCK
47½	25	None
49½	35	5
55	50	8½

Car Wheel Lathe, Centre Drive

SWING IN INCHES	HP. OF MOTORS	
	MAIN	TAIL STOCK
42	50	5

Westinghouse Electric & Manufacturing Company
East Pittsburgh, Penna.

DIRECT CURRENT REVERSING MOTOR PLANER EQUIPMENT

Constant Voltage

This equipment employs the use of an adjustable speed motor with range of adjustment from 250 to 1000 r.p.m. and a control panel to provide reversing and dynamic braking at the end of each stroke. The lower half of the range (250 to 500 r.p.m.) is used for the cutting stroke and the upper half (500 to 1000 r.p.m.) for the return stroke. All speed adjustment is obtained by means of field weakening resistance. These equipments are built in the following horsepower sizes, 230 volts only, 5-10-15-20-25-35-50-75.

Variable Voltage

This equipment is particularly adaptable where direct current is not available or where a wider range of speed is desired than is possible with the constant voltage equipment. It consists of a variable voltage motor generator furnishing power to an adjustable speed direct current motor. The total speed range is 200 to 1200 r.p.m., part of which is obtained by means of varying the generator voltage and the remainder by field control of the motor. These two variables are combined in order to obtain a cutting speed range of 200 to 800 r.p.m. and a return speed range of 500 to 1200 r.p.m. These equipments are built in the following horsepower sizes; 15-25-35-50-75. The driving motor of the motor generator can be supplied for connection to any commercial power circuit.

RECOMMENDED MOTOR RATINGS

WIDTH OF PLANER HOUSING IN INCHES	LENGTH OF PLANER IN FEET	MOTOR HP.
36	8 to 16	5
36	18 to 24	10
42	8 to 16	15 to 20
42	18 to 24	20 to 25
48	8 to 12	20 to 25
48	14 to 24	25 to 35
60	10 to 12	20 to 25
60	16 to 20	25 to 35
72	14 to 20	35 to 60
84	14 to 20	35 to 50
96	18 to 24	50 to 75
120	18 to 24	50 to 75
Frog & Switch old type	35
Frog & Switch later than 1922	50

TURNTABLES AND TRANSFER TABLES

Modern turntables are of the continuous girder type, the girder being approximately 110 feet long, supported equally at the center and the two ends. The motors for driving the table are usually mounted directly on the trucks at each end of the girder and are geared directly to the table wheel shafts. Two motors are used and are operated by one duplex controller. The control circuits are usually carried through suitable disconnecting switches so that in the event of trouble with one motor, the table may be operated by the second motor.

The motors used on these tables are usually rated at 20 hp. to 25 hp. for intermittent duty. When direct current service is available, series type motors are used, and when only alternating current service is available, wound rotor motors are used.

The method of braking tables varies with the turntable manufacturers and the various railroads. Many tables are equipped with only mechanical brakes which are operated either by a hand lever or a foot pedal. On the other hand there now seems to be a marked tendency toward the application of magnetic electric brakes for this service. The principal reason for this is that when mechanical brakes are provided the table operators quickly discover that they can stop the tables with much less physical exertion by "plugging" or reversing the motors. However, this practice imposes on the motors additional duty for which they were not intended and results in damage to the equipment. This is obviated by providing magnetic brakes.

Some large tables are operated by motor driven tractors located at each end of the table in which case the motor and control equipment is the same as that described above. However, smaller tables, 75 feet, 85 feet and 100 feet long are usually operated by a single tractor located at one end of the table.

Where only one motor is used on a table it is usually rated at 25 hp. to 30 hp., and is of the same type as for double motor equipment. The controller, however, is somewhat smaller.

The turntable controllers supplied by the Westinghouse Company are of the cam operated contactor type and can be used with either A-C. or D-C. motors by making a few simple changes in the internal wiring. The contacts of the contactors are also interchangeable with those of the same capacity on other starters and controllers designed for general purpose motors. Both of these features greatly

Westinghouse Electric & Manufacturing Company
East Pittsburgh, Penna.

S. P. 1707
Sheet 23

G-24

Printed in U. S. A.

GENERAL MOTOR DATA (Cont.)

If true power is expressed in kilowatts (kw.) and apparent power as the product of kilovolts (1000 volts) and amperes or kv-a.

$$\text{Power factor (P.F.)} = \frac{\text{Kw.}}{\text{Kv-a.}}$$

Three-Phase Connections. Three-phase circuits may be connected in delta (Δ) or in star (Y) as illustrated. If three transformers are connected in delta, the voltage across each transformer is the same as the line voltage ($E_l = E$); the current in each line wire is the instantaneous sum of the currents through two transformers ($I = 1.7321 I_t$). If three transformers are connected in star, $E = 1.732 E_l$ and $I = I_t$.

Measurement of A-C. Power. If W = watts, E = average volts between line terminals, I = average line current, and P.F. = power factor expressed as a decimal fraction, the following formula represent their relations:

$$\begin{aligned} \text{Single-phase } W &= EI \times \text{P.F.} \\ \text{Two-phase } W &= 2EI \times \text{P.F.} \\ \text{Three-phase } W &= 1.732 EI \times \text{P.F.} \end{aligned}$$

From the above formula the current can be found as follows:

$$\begin{aligned} \text{Single-phase } I &= \frac{W}{E \times \text{P.F.}} \\ \text{Two-phase } I &= \frac{W}{2 E \times \text{P.F.}} = \frac{.5 W}{E \times \text{P.F.}} \\ \text{Three-phase } I &= \frac{W}{1.732 E \times \text{P.F.}} = \frac{.578 W}{E \times \text{P.F.}} \end{aligned}$$

Effect of Changes of Voltage and Frequency

The starting torque of an induction motor will vary as the square of the voltage applied to the primary; hence, the primary voltage required to produce a given starting torque can be determined by means of the formula:

$$V_1 = V \sqrt{\frac{T_1}{T}}$$

Westinghouse Electric & Manufacturing Company
East Pittsburgh, Penna.

S. P. 1707
Sheet 24

6-24

Printed in U. S. A.

Where V_1 and T_1 signify required voltage and torque respectively, V , the full rated voltage, and T , the starting torque at full voltage. For example: if a squirrel cage induction motor is required to start with full load torque only, and if the starting torque at full voltage is 2.5 times full load torque (2.5 F.L.T.) the starting voltage should be:

$$V_1 = V \sqrt{\frac{1}{2.5}} = .63 V; \text{ that is, the starting voltage should be } 63\% \text{ of full voltage.}$$

The starting current of squirrel cage induction motors depends on the starting voltage applied and is independent of the torque required to start the load; the current falls almost immediately, however, to the value corresponding to the required torque and then decreases more gradually as the motor speed accelerates. From this, it follows that the starting voltage should not be greatly in excess of that required for the torque.

Wound rotor motors when started by means of resistance in the secondary circuits can usually be accelerated to full speed with full load torque with current very little in excess of full load current.

A variation in either voltage or frequency not exceeding 10% is generally permissible with any induction motor. Such variations are always accompanied by changes from normal performance with either the voltage or the frequency differing from normal; the following performance change will be obtained:

CHARACTER OF CHANGE	EFFECT ON			
	POWER FACTOR	TORQUE	SLIP	EFFICIENCY
Voltage higher	Decreased	Increased	Decreased	Decreased
Voltage lower	Increased	Decreased	Increased	Increased
Frequency higher	Increased	Decreased	% Slip unchanged	Increased
Frequency lower	Decreased	Increased	% Slip unchanged	Decreased

The voltage and frequency should not be varied simultaneously in opposite directions, that is, one increased and the other decreased. If an induction motor must operate on frequency other than standard, the performance will be better if the voltage is changed in proportion to the square root of the frequency. For example: a 220-volt, 60-cycle motor, operating on 50 cycles, will have very nearly its normal performance if the voltage is decreased

$$\text{to } 220 \times \sqrt{\frac{50}{60}} = 200.$$

GENERAL MOTOR DATA

Approximate Amperes per Terminal for Alternating-Current Induction Motors For Determining Size of Wire, Capacity of Fuse and Setting of Circuit-Breaker

Hp. of Motor	110 Volts		220 Volts		440 Volts		550 V.	1100 V.	2200 V.
	2-Ph.	3-Ph.	2-Ph.	3-Ph.	2-Ph.	3-Ph.	3-Ph.	3-Ph.	3-Ph.
1/2	3.3	3.7	1.7	1.8	.9	1	—	—	—
1	6	6.5	3	3.2	1.5	1.6	—	—	—
2	10.5	12	5	6	2.9	3	2.5	—	—
3	15	17	7.5	9	3.8	4.5	3.5	—	—
5	27	30	13	15	6.5	7.5	6	—	—
7 1/2	—	—	20	22	10	11	9	—	—
10	—	—	25	29	12.5	14	11	—	—
15	—	—	35	41	18	20	16	—	—
20	—	—	43	55	24	27	22	—	—
25	—	—	54	69	27	31	25	—	—
30	—	—	70	81	35	40	32	16	8
40	—	—	95	109	47	54	44	22	11
50	—	—	110	127	55	64	52	27	13
75	—	—	165	192	83	96	77	39	20
100	—	—	215	243	108	124	100	50	25
150	—	—	320	366	160	183	147	80	40
200	—	—	410	475	205	237	192	98	49
250	—	—	510	590	250	290	237	125	62
300	—	—	600	700	300	350	287	150	74

Copyright June 1924 by W. E. & M. Co.

For single-phase motors multiply the current per terminal for a two-phase motor by two.

Horsepower is a measure of the time rate of doing work and is defined as the equivalent of raising 33,000 pounds one foot in one minute. 1 hp. is equivalent to 746 watts.

Torque is the pull or turning moment required in applying power by rotation and varies inversely as the radius at which the power is applied. The torque T is expressed in pounds at one foot radius, sometimes called pound-feet.

Full Load Torque is the turning moment required to develop full rated output of a motor of given horsepower at a given speed.

The torque T of any motor at any output expressed in pounds at one foot radius can be found by means of the following formula:

$$T = \frac{5250 \times \text{Hp.}}{\text{R.p.m.}}$$

Westinghouse Electric & Manufacturing Company
East Pittsburgh, Penna.

S. P. 1707
Sheet 24

6-24

Printed in U. S. A.

Conversely if the torque in pounds at one foot radius is known, the horsepower at any given speed can be determined from the formula:

$$\text{Hp.} = \frac{T \times \text{R.p.m.}}{5250}$$

Starting Torque is the turning moment a motor will develop in starting with a given starting voltage impressed. Starting torque is expressed in terms of full load torque, as 1.5 times full load torque, and generally on the basis of full voltage regardless of whether this is actually used in starting or not.

Pull Out Torque, or maximum running torque is the maximum turning moment a motor will develop under running conditions with rated voltage applied.

Amperes for Direct Current Motors. The relation of the horsepower (Hp.), the volts (E), the amperes (I) and the efficiency in percent (e) of the electric motor is expressed by the formula:

$$\text{Hp.} = \frac{E I e}{746}$$

This formula contains four quantities indicated by letters; if any three are known or can be assumed, the other one can be found. Efficiencies of industrial motors can be assumed at from 80% to 90%, depending upon the size.

For example, to determine the current required by a 10 hp., 220-volt motor of which the efficiency is unknown, assume 85% as an approximate value and apply the formula:

$$10 = \frac{220 \times I \times .85}{746}$$

$$\text{Therefore } I = \frac{10 \times 746}{220 \times .85} = 40 \text{ Approx.}$$

A rough approximation in determining the current required by direct-current motors is as follows:

- 8 amperes per hp. for 110-115-volt motors.
- 4 amperes per hp. for 220-230-volt motors.
- 1 3/4 amperes per hp. for 500-volt motors.

Power Factor is the ratio of the true power (kw. or wattmeter reading) to the apparent power (kv-a. or product of voltmeter and ammeter readings). The ratio is usually expressed in percent and cannot be greater than 100%.

GENERAL MOTOR DATA (Cont.)

If true power is expressed in kilowatts (kw.) and apparent power as the product of kilovolts (1000 volts) and amperes or kv-a.

$$\text{Power factor (P.F.)} = \frac{\text{Kw.}}{\text{Kv-a.}}$$

Three-Phase Connections. Three-phase circuits may be connected in delta (Δ) or in star (Y) as illustrated. If three transformers are connected in delta, the voltage across each transformer is the same as the line voltage ($E_l = E$); the current in each line wire is the instantaneous sum of the currents through two transformers ($I = 1.732 I_t$). If three transformers are connected in star, $E = 1.732 E_t$ and $I = I_t$.

Measurement of A-C. Power. If $W =$ watts, $E =$ average volts between line terminals, $I =$ average line current, and P.F. = power factor expressed as a decimal fraction, the following formula represent their relations:

Single-phase $W = EI \times \text{P.F.}$
 Two-phase $W = 2EI \times \text{P.F.}$
 Three-phase $W = 1.732 EI \times \text{P.F.}$

From the above formula the current can be found as follows:

Single-phase $I = \frac{W}{E \times \text{P.F.}}$
 Two-phase $I = \frac{W}{2 E \times \text{P.F.}} = \frac{.5 W}{E \times \text{P.F.}}$
 Three-phase $I = \frac{W}{1.732 E \times \text{P.F.}} = \frac{.578 W}{E \times \text{P.F.}}$

Effect of Changes of Voltage and Frequency

The starting torque of an induction motor will vary as the square of the voltage applied to the primary; hence, the primary voltage required to produce a given starting torque can be determined by means of the formula:

$$V_1 = V \sqrt{\frac{T_1}{T}}$$

Westinghouse Electric & Manufacturing Company
 East Pittsburgh, Penna.

Where V_1 and T_1 signify required voltage and torque respectively, V , the full rated voltage, and T , the starting torque at full voltage. For example: if a squirrel cage induction motor is required to start with full load torque only, and if the starting torque at full voltage is 2.5 times full load torque (2.5 F.L.T.) the starting voltage should be:

$$V_1 = V \sqrt{\frac{1}{2.5}} = .63 V; \text{ that is, the starting voltage should be } 63\% \text{ of full voltage.}$$

The starting current of squirrel cage induction motors depends on the starting voltage applied and is independent of the torque required to start the load; the current falls almost immediately, however, to the value corresponding to the required torque and then decreases more gradually as the motor speed accelerates. From this, it follows that the starting voltage should not be greatly in excess of that required for the torque.

Wound rotor motors when started by means of resistance in the secondary circuits can usually be accelerated to full speed with full load torque with current very little in excess of full load current.

A variation in either voltage or frequency not exceeding 10% is generally permissible with any induction motor. Such variations are always accompanied by changes from normal performance with either the voltage or the frequency differing from normal; the following performance change will be obtained:

CHARACTER OF CHANGE	EFFECT ON			
	POWER FACTOR	TORQUE	SLIP	EFFICIENCY
Voltage higher	Decreased	Increased	Decreased	Decreased
Voltage lower	Increased	Decreased	Increased	Increased
Frequency higher	Increased	Decreased	% Slip unchanged	Increased
Frequency lower	Decreased	Increased	% Slip unchanged	Decreased

The voltage and frequency should not be varied simultaneously in opposite directions, that is, one increased and the other decreased. If an induction motor must operate on frequency other than standard, the performance will be better if the voltage is changed in proportion to the square root of the frequency. For example: a 220-volt, 60-cycle motor, operating on 50 cycles, will have very nearly its normal performance if the voltage is decreased

$$\text{to } 220 \times \sqrt{\frac{50}{60}} = 200.$$

POWER FACTOR CORRECTION

The question of power factor correction is obviously an economic one, the total of the monetary and capitalized advantages through correction being balanced against the total operating cost (not first cost alone) of the corrective equipment applied.

The synchronous motor furnishes a method of correction which should always be given consideration. In railway shops these motors may be advantageously applied to compressors, fans, blowers, centrifugal pumps and other constant speed loads. The service must be one in which the motor can be in operation continuously, as is particularly evident in connection with the large number of power factor penalty clauses which operate upon the maximum kv-a. plant demand over an interval of stated duration.

The synchronous condenser furnishes the most economical corrective method in many cases, although the entire operating cost of the equipment must be charged to power factor correction. It seldom proves economically preferable for ratings below 150 kv-a.

The static condenser often shows economies better than those of any of the other types, chiefly because of the low energy cost involved in operating this type of equipment.

The following example shows the method of calculating the kv-a. capacity of a condenser needed to correct the power factor a definite amount for any given load. The kv-a. required to correct from a given initial to a given final power factor is entirely dependent on the load on the plant, as a condenser which would correct a 100 kw. load from 50 percent power factor to unity would increase the power factor to 76 percent if the load became 200 kw. at the same initial power factor.

(See over for example)


Westinghouse Electric & Manufacturing Company
East Pittsburgh, Penna.

S. P. 1707
Sheet 25

6-24

Printed in U. S. A.

Example—Plant whose average load is 200 kw. and average power factor 60. It is desired to correct the power factor to 90.



Present load = 200 kw. at 60 percent power factor.

Desired power factor = 90

$$\text{Present kv-a.} = \frac{200}{.60} = 334$$

$$\text{Present reactive kv-a.} = \sqrt{334^2 - 200^2} = 268$$

$$\text{Kv-a. at desired power factor} = \frac{200}{.90} = 222$$

$$\text{Reactive kv-a. at desired power factor} = \sqrt{222^2 - 200^2} = 96.5$$

$$\text{Corrective effect needed} = 268 - 96.5 = 171.5 \text{ kv-a.}$$

Size of standard condenser: Static, 180 kv-a; Synchronous 200 kv-a.

GENERAL DATA

Weight and Specific Gravity of
Various Materials

Material	Specific Gravity	Pounds Per Cubic Foot
Brick, fire	2.24-2.4	140-150
Brick, hard	2.0	125
Brick, soft	1.6	100
Brickwork in mortar	1.6	100
Brickwork in cement	1.79	112
Cement loose, Portland	1.25	78
Concrete	1.92-2.24	120-140
Earth, loose	1.15-1.28	72- 80
Earth, rammed	1.44-1.76	90-110
Gravel	1.6 -1.92	100-120
Lime, quick in bulk8 - .88	50- 55
Masonry	2.24-2.88	140-180
Mortar	1.44-1.6	90-100
Sand	1.44-1.76	90-110
Slate	2.72-2.88	170-180
Soapstone	2.65-2.8	166-175
Stone, various	2.16-3.4	135-200
Trap	2.72-3.4	170-200
Tile	1.76-1.92	110-120

Copyright June 1924 by W. E. & M. Co.

Westinghouse Electric & Manufacturing Company
East Pittsburgh, Penna.S. P. 1707
Sheet 26

6-24

Printed in U. S. A.

Resistances and Weights of Trolley, Feeder and Rail—Single Track, Single Trolley

Size of Trolley B & S	Size of Feeder B & S	Pounds Per Mile		Rail Lb. Per Yard	Size of Bonds		Ohms Per Mile			
		Trolley	Feeder		Length In.	B & S	Trolley	Feeder	Track	Total
000	2740	50	28	000	0.339	0.066	0.405
000	0000	2740	3450	60	10	000	0.339	0.269	0.049	0.199
000	0000	2740	3450	70	10	0000	0.339	0.269	0.042	0.192
0000	0000	3450	3450	80	10	000	0.269	0.269	0.037	0.171
0000	0000	3450	3450	60	28	000	0.269	0.269	0.055	0.189
0000	300000	3450	4900	70	10	000	0.269	0.190	0.042	0.153
0000	500000	3450	8125	80	10	000	0.269	0.114	0.037	0.117
0000	750000	3450	12240	90	12	350m	0.269	0.076	0.032	0.091
0000	300000	3450	4900	70	28	0000	0.269	0.190	0.048	0.159
0000	400000	3450	6550	70	10	0000	0.269	0.142	0.042	0.135
0000	500000	3450	8125	70	10	0000	0.269	0.114	0.042	0.122
0000	600000	3450	9760	70	10	0000	0.269	0.0950	0.042	0.112
0000	790000	3450	11400	70	10	0000	0.269	0.0812	0.042	0.1044
0000	800000	3450	13040	70	10	0000	0.269	0.0712	0.042	0.0983
0000	900000	3450	15200	70	10	0000	0.269	0.0634	0.042	0.0933
000	1000000	3450	16320	70	10	0000	0.269	0.0570	0.042	0.0890
000	1250000	3450	20410	90	12	350m	0.269	0.0455	0.032	0.0709
000	1500000	3450	24430	90	12	350m	0.269	0.0379	0.032	0.0652
0000	1750000	3450	28550	90	12	350m	0.269	0.0325	0.032	0.0610
0000	2000000	3450	32610	90	12	350m	0.269	0.0279	0.032	0.0573

GENERAL DATA

Conversion Factors

MULTIPLY	BY	TO OBTAIN
Acres.....	.43560.....	Square Feet
Acres.....	.4047.....	Square Meters
Acres.....	1.562×10^{-3}	Square Miles
Acres.....	.4840.....	Square Yards
Acre-Feet.....	.43560.....	Cubic Feet
Acre-Feet.....	3.259×10^{-5}	Gallons
Atmospheres.....	.76.0.....	Cms. of Mercury
Atmospheres.....	.29.92.....	Inches of Mercury
Atmospheres.....	.33.90.....	Feet of Water
Atmospheres.....	.14.70.....	Pounds per Sq. In.
Board-Feet.....	.144 Sq. In. x 1 In.....	Cubic Inches
British Thermal Units.....	.777.5.....	Foot-Pounds
British Thermal Units.....	2.928×10^{-4}	Kilowatt-Hours
Bushels.....	.1.244.....	Cubic Feet
Bushels.....	.2150.....	Cubic Inches
Centimeters.....	.0.3937.....	Inches
Circular Mils.....	5.087×10^{-6}	Square Centimeters
Circular Mils.....	7.854×10^{-7}	Square Inches
Circular Mils.....	.0.7854.....	Square Mils
Cubic Feet.....	2.832×10^{-4}	Cubic Cms.
Cubic Feet.....	.1728.....	Cubic Inches
Cubic Feet.....	.0.03704.....	Cubic Yards
Cubic Feet.....	.7.481.....	Gallons
Cubic Feet Per Minute.....	.0.1247.....	Gallons Per Sec.
Cubic Yards.....	.27.....	Cubic Feet
Cubic Yards.....	.46656.....	Cubic Inches
Cubic Yards.....	.202.0.....	Gallons
Days.....	.1440.....	Minutes
Days.....	.86400.....	Seconds
Degrees (angle).....	.60.....	Minutes
Degrees (angle).....	.0.01745.....	Radians
Degrees Per Second.....	.0.1667.....	Revolutions per Min.
Feet.....	.0.3048.....	Meters
Feet Per Minute.....	.0.01136.....	Miles Per Hour
Feet Per Second.....	.0.6818.....	Miles Per Hour
Feet Per Sec. Per Sec.....	.0.6818.....	Miles per Hr. Per Sec.
Foot-Pounds.....	1.286×10^{-3}	British Thermal Units
Foot-Pounds.....	3.766×10^{-7}	Kilowatt-Hours
Foot-Pounds Per Min.....	3.030×10^{-5}	Horsepower
Foot-Pounds Per Min.....	2.260×10^{-5}	Kilowatts
Foot-Pounds Per Sec.....	1.818×10^{-3}	Horsepower
Foot-Pounds Per Sec.....	1.356×10^{-3}	Kilowatts

Copyright June 1924 by W. E. & M. Co.

Westinghouse Electric & Manufacturing Company
East Pittsburgh, Penna.

S. P. 1707
Sheet 27

6-24

Printed in U. S. A.

MULTIPLY	BY	TO OBTAIN
Furlongs.....	40.....	Rods
Gallons.....	0.1337.....	Cubic Feet
Gallons.....	231.....	Cubic Inches
Grams.....	980.7.....	Dynes
Grams.....	0.03527.....	Ounces
Gram Calories.....	3.968×10^{-6}	British Thermal Units
Horsepower.....	42.44.....	B. T. U. Per Min.
Horsepower.....	33000.....	Ft.-Lb. Per Min.
Horsepower.....	1.014.....	Metric Horsepower
Horsepower.....	0.7457.....	Kilowatts
Horsepower (boiler).....	33520.....	B. T. U. Per Hour
Inches.....	2.540.....	Centimeters
Inches.....	10^{-3}	Mils
Kilograms.....	2.205.....	Pounds
Kilometers.....	0.6214.....	Miles
Kilometers Per Hour.....	0.6214.....	Miles Per Hour
Kilometers Per Hour.....	54.68.....	Feet Per Minute
Kilometers Per Hr. Per Sec.....	0.6214.....	Miles Per Hr. Per Sec.
Knots.....	6080.....	Feet
Knots.....	1.152.....	Miles
Links (Surveyors).....	7.92.....	Inches
Log ₁₀ N.....	2.303.....	Ln N
Meters.....	3.281.....	Feet
Meters.....	39.37.....	Inches
Meters.....	1.094.....	Yards
Miles.....	1.609.....	Kilometers
Miles.....	1760.....	Yards
Miles Per Hour.....	88.....	Feet Per Minute
Miles Per Hour.....	1.467.....	Feet Per Second
Miles Per Hr. Per Sec.....	1.467.....	Feet Per Sec. Per Sec.
Miles Per Hr. Per Sec.....	0.4470.....	Meters per Sec. Per Sec.
Ohms Per Mil.-Ft.....	0.1662.....	Microhms Per Cm. Cube
Perches (masonry).....	24.75.....	Cubic Feet
Pounds Per Ton.....	0.5.....	Kilograms Per Metric Ton
Rods.....	16.5.....	Feet
Square Centimeters.....	1.973×10^{-6}	Circular Mils
Temp. (degs. Fahr)-32.....	$5/9$	Temp (deg. Cent.)
Tons (long).....	1016.....	Kilograms
Tons (long).....	2240.....	Pounds
Tons (metric).....	2205.....	Pounds
Years.....	8760.....	Hours